

# MICROTECH<sup>®</sup>

## UNIT CONTROLLER PROTOCOL INFORMATION

Used on Chiller Models AGZ-F, WMC-E, and WMT  
BACnet<sup>®</sup> Networks (MS/TP, IP)  
Modbus<sup>®</sup> Networks



<b>Introduction</b> . . . . .	<b>3</b>	<b>Alarm Management</b> . . . . .	<b>25</b>
Hazard Identification . . . . .	3	Alarm Classes . . . . .	25
Revision History . . . . .	3	BACnet Alarms . . . . .	26
Limited Warranty . . . . .	3	<b>Appendix A: PICS Statement</b> . . . . .	<b>38</b>
Reference Documents . . . . .	3	BACnet Protocol Implementation Conformance Statement . . . . .	38
Software Revision . . . . .	3	Converting Register Values to ASCII Characters . . . . .	46
<b>Basic Protocol Information</b> . . . . .	<b>4</b>		
Unit Controller Data Points . . . . .	4		
Protocol Definitions . . . . .	4		
BACnet Protocol . . . . .	4		
Modbus Protocol . . . . .	4		
Setting BAS Communication Parameters . . . . .	4		
Communication Parameter Settings . . . . .	4		
BACnet Networks Compatibility . . . . .	5		
BACnet Objects . . . . .	5		
Chiller Unit Controller Device Object . . . . .	5		
Device Object Identifier . . . . .	5		
Device Object Properties . . . . .	6		
<b>Network Considerations</b> . . . . .	<b>7</b>		
Access to Properties . . . . .	7		
BACnet IP Network Addressing . . . . .	7		
Shared Ethernet Networks . . . . .	7		
BACnet MS/TP Network Addressing . . . . .	7		
Modbus Networks . . . . .	7		
Valid Function Codes . . . . .	7		
Configuring the Unit Controller . . . . .	9		
<b>Comprehensive Data Tables</b> . . . . .	<b>10</b>		
Network Parameters . . . . .	10		
BACnet Network Objects . . . . .	11		
Modbus Register Mapping . . . . .	18		

©2026 Daikin Applied, Minneapolis, MN. All rights reserved throughout the world. This document contains the most current product information as of this printing. Daikin Applied Americas Inc. has the right to change the information, design, and construction of the product represented within the document without prior notice. For the most up-to-date product information, please go to [www.DaikinApplied.com](http://www.DaikinApplied.com).

™@ MicroTech, and Daikin Applied are trademarks or registered trademarks of Daikin Applied Americas Inc. The following are trademarks or registered trademarks of their respective companies: BACnet from American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.; Echelon, LonWorks, LonMark, and LonTalk from Echelon Corporation; Modbus from Schneider Electric; and Windows from Microsoft Corporation.

# Introduction

## Hazard Identification

### DANGER

Danger indicates a hazardous situation, which will result in death or serious injury if not avoided.

### WARNING

Warning indicates a potentially hazardous situations, which can result in property damage, personal injury, or death if not avoided.

### CAUTION

Caution indicates a potentially hazardous situations, which can result in minor injury or equipment damage if not avoided.

### NOTICE

Notice indicates practices not related to physical injury.

## Revision History

Part Number	Release Date	Revision Description
ED19131	May 2024	Initial Release
ED19131-1	April 2026	Addition of WMC-E Chiller Model

## Limited Warranty

Consult your local Daikin Applied Representative for warranty details. To find your local Daikin Applied Representative, go to [www.DaikinApplied.com](http://www.DaikinApplied.com).

This document contains the information necessary to incorporate a Daikin Applied MicroTech® Chiller Unit Controller, subsequently referred to as the Chiller Unit Controller, into a building automation system (BAS). It lists all BACnet properties, Modbus registers, and corresponding Chiller Unit Controller data points. It also contains the BACnet Protocol Implementation Conformance Statement (PICS). BACnet and Modbus terms are not defined. Refer to the respective specifications for definitions and details.

## Reference Documents

Company	Number	Title	Source
Daikin Applied	IOM 1359	Trailblazer® Model AGZ, F-Vintage Air Cooled Chiller Installation, Operation and Maintenance Manual	<a href="http://www.DaikinApplied.com">www.DaikinApplied.com</a>

Company	Number	Title	Source
Daikin Applied	IOM 1297	Magnitude® Model WMT Magnetic Bearing Centrifugal Chiller Installation, Operation, and Maintenance Manual	<a href="http://www.DaikinApplied.com">www.DaikinApplied.com</a>
Daikin Applied	IOM 1389	Magnitude® Model WMC-E Magnetic Bearing Centrifugal Chiller Installation, Operation, and Maintenance Manual	<a href="http://www.DaikinApplied.com">www.DaikinApplied.com</a>
Daikin Applied	IM 1283	MicroTech® Chiller Unit Controller BACnet® IP, BACnet MS/TP®, and Modbus® Communication Module	<a href="http://www.DaikinApplied.com">www.DaikinApplied.com</a>
American Society of Heating, Refriger, and Air-Conditioning Engineers	ANSI/ASHRAE 135-2012	BACnet A Data Communication Protocol for Building Automation and Control Networks	<a href="http://www.ashrae.org">www.ashrae.org</a>
Modbus-IDA.ORG		Modbus Application Protocol Specification V1.1b	<a href="http://www.Modbus.org">www.Modbus.org</a>
Modbus-IDA.ORG		Modbus over Serial Line Specification and Implementation Guide V1.02	<a href="http://www.Modbus.org">www.Modbus.org</a>

## Software Revision

This document supports the following versions of the standard chiller unit controller application and all subsequent versions until otherwise indicated. However, if the unit software is of a later version, some of the information in this document may not completely describe the application.

Chiller Model	Chiller Application Software Version	Chiller HMI Software Version	Communication Module Software Version
Trailblazer Model AGZ, F-Vintage Air Cooled Chiller	1.2.0 Installer		1.12.0
Magnitude WMT Magnetic Bearing Centrifugal Chiller	1.0.0 Installer		1.0.0
Magnitude WMC-E Magnetic Bearing Centrifugal Chiller	1.0.0 Installer		1.0.0

The revision of the application software can be determined from the chiller HMI under the 'Settings' menu.

# Basic Protocol Information

## Unit Controller Data Points

The Chiller Unit Controller contains data points or unit variables that are accessible from several user interfaces: the local Human Machine Interface (HMI), a BACnet network (BACnet IP or MS/TP), or a Modbus network. Not all points are accessible from each interface. This manual lists all important data points and the corresponding path for each applicable interface. Refer to the respective chiller operation manual, available on [www.DaikinApplied.com](http://www.DaikinApplied.com), for HMI display details.

## Protocol Definitions

Building Automation System (BAS) communication to the chiller unit controller can be configured in either an interoperable BACnet or Modbus network. This requires a BAS module, which can be ordered with the chiller and factory-mounted or can be field-mounted at any time after the chiller unit is installed. Connection to the chiller for all BAS protocols will be at the BAS module.

## BACnet Protocol

BACnet is a standard communication protocol for Building Automation and Control Networks developed by the American National Standards Institute (ANSI) and American Society of Heating, Refrigeration and Air-conditioning Engineers (ASHRAE) specified in ANSI/ASHRAE standard 135-2012. It addresses all aspects of the various systems that are applied to building control systems. BACnet provides the communication infrastructure needed to integrate products manufactured by different vendors and to integrate building services that are now independent.

## Modbus Protocol

The Modbus protocol is a standardized Application Level (OSI Level 7) protocol used in interoperable Industrial Control networks. Modbus provides the communication infrastructure necessary to integrate products manufactured by different vendors and to integrate control services that are now independent. The Modbus protocol specifies how requests from the client are sent to a server and how servers reply. The client constructs a PDU (protocol data unit) and sends it to a specific server or broadcasts it to all servers.

The PDU contains a function code that defines the action the client is requesting from the server(s). The PDU also includes a data field that further defines the action to the server, for example, the location of the data to be read. A normal reply from a server includes the same function code and a response data field. In the case of a read operation, the response data field contains the requested data. In the case of a write operation, the response data field contains an echo of the write data of the request command. If the server detects an error in the transmission, the reply to the client includes an exception function code and the response data field contains an exception

code.

Controllers can communicate on standard Modbus networks using one of two transmission modes: ASCII or RTU. Users select the serial port communication parameters (baud rate, parity mode, etc.), during configuration of the controller. The mode and serial parameters must be the same for all devices on a Modbus network. Transmission mode determines how information is packed into the message fields and decoded. In RTU mode, each byte contains two hexadecimal characters, and in ASCII mode, each byte contains one ASCII character.

**NOTICE**

The Chiller Unit Controller uses the RTU mode only.

## Setting BAS Communication Parameters

There are various parameters involved in setting up the unit controller with three communication module options (BACnet IP, BACnet MS/TP or Modbus). These parameters are set differently depending on which communication module is ordered and shipped with the unit. The table below lists the three possible sets of default parameter settings. Not all the parameters apply to all the module options. The bold parameters can be changed using the HMI display located on the unit. The parameters in italics must be changed in the BACnet Device Object.

## Communication Parameter Settings

**Table 1: Communication Parameter Settings**

Parameter Name	BACnet IP	BACnet MS/TP	Modbus
Device Instance	9050	9050	N/A
IP Address	192.168.1.10	N/A	N/A
IP Gateway	192.168.1.1	N/A	N/A
IP Mask	255.255.255.0	N/A	N/A
UDP Port Number	47808	NA	N/A
MS/TP MAC Address	N/A	1	N/A
Baud Rate	N/A	38400	19200
Device Object Name	Daikin_Micro-Tech_#####, where ##### is the Device Instance	Daikin_Micro-Tech_#####, where ##### is the Device Instance	N/A
Max Info Frames	N/A	10	N/A
Max Master	N/A	127	N/A
Modbus Address	N/A	N/A	1
Parity	N/A	N/A	None
Modbus Stop Bits	N/A	N/A	1

## BACnet Networks Compatibility

The chiller unit controller is tested according to the BACnet Testing Laboratory (BTL) Test Plan. It is designed to meet the requirements of the BACnet Standard (ANSI/ASHRAE 135-2012) as stated in the Protocol Implementation and Conformance Statement (PICS). The PICS is located at the end of this manual.

## BACnet Objects

Chiller unit controllers incorporate standard BACnet object types (i.e., object types defined in the BACnet Standard) that conform to the BACnet Standard. Each object has properties that control unit variables or data points. Some object types occur more than once in the chiller unit controller; each occurrence or instance has different properties and controls different unit variables or data points. Each instance is designated with a unique instance index. Some properties can be adjusted (read/write properties, e.g., setpoints) from the network and others can only be interrogated (read-only properties, e.g., status information). The Object Name is the name of the object in the device. Object Names must be unique within each BACnet device.

The Object Name, along with the Object Type and Instance Number, are described in the “Comprehensive Data Tables” section. For more information on Object Types, please refer to ASHRAE Standard 135-2012 ([www.ashrae.org](http://www.ashrae.org))

## Chiller Unit Controller Device Object

### CAUTION

If another device in the network already has this object identifier (instance number) and device object name, the instance number and device object name of one device must be changed, so that all devices in the network have a unique instance number and device object name.

Each BACnet compatible device (i.e. chiller unit controller) can only have a single BACnet Device Object.

## Device Object Identifier

The Chiller Unit Controller Device Object Identifier (Device Instance Number) uniquely specifies the unit within the network. This number must be unique on the entire BACnet network. The default device instance number is 9050, but can be changed via the HMI. Cycle power on the BAS module for the change to take effect.

## Device Object Properties

The Device Object contains other informative properties as shown in [Table 2](#).

**Table 2: Chiller Unit Controller Device Object Properties**

Property	Identifier	Default Value	Data Type
Object Identifier	75	Device-9050 (Device- followed by Instance Number)	BACnetObjectIdentifier
Object Name	77	Daikin_MicroTech_#####, where ##### is the Device Instance	Character String
Object Type	79	0	BACnetObjectType
System Status	112	Operational (0)	BACnetDeviceStatus
Vendor Name	121	Carel Industries S.p.A.	Character String
Vendor Identifier	120	77	Unsigned 16
Model Name	70	pCOmini	Character String
Firmware Revision	44	4.3.000	Character String
Application Software Version	12	1.00.030	Character String
Location	58		Character String
Description	28	Carel Multitasking Controller	Character String
Protocol Version	98	1	Unsigned
Protocol Services Supported	97	acknowledgeAlarm, getAlarm-Summary, getEnrollmentSummary, subscribeCOV, atomicReadFile, atomicWriteFile, readProperty, readPropertyMultiple, writePropertyMultiple, deviceCommunicationControl, reinitializeDevice, i-Am, timeSynchronization, who-Has, who-Is, readRange, utcTimeSynchronization, subscribeCOVProperty, getEventInformation	BACnetServicesSupported
Protocol Object Types Supported	96	analog-input, analog-value, binary-input, binary-value, calendar, device, file, schedule, multi-state-value, trend-log, analog-output, binary-output, integer-value, multistate-input, multistate-output, notification-class, and positive-integer-value to this list	BACnetObjectTypesSupported
Object List	76		Sequence of BACnetObjectIdentifier
Max APDU Length Accepted	62	1024 (IP) / 480 (MS/TP)	Unsigned 16
Segmentation Supported	107	Both	BACnetSegmentation
Max Segments Accepted	167	16	Unsigned
Local Time	57	variable	Time
Local Date	56	variable	Date
UTC Offset	119	-0 (Range: -780 .. 780)	Integer
Daylight Savings Status	24	variable	Boolean
APDU Segment Timeout	10	5000	Unsigned
APDU Timeout	11	1500	Unsigned
Number of APDU Retries	73	2	Unsigned
Device Address Binding	30	variable	Sequence of BACnetAddressBinding
Active COV Subscriptions	152	variable	List of BACnetCOVSubscriptions

# Network Considerations

## Access to Properties

Object properties are accessible from the network by specifying three identifiers: the device object identifier, object identifier, and the property identifier. To access a property, the user must specify the object identifier including the device object identifier or the object name including the device object name and the property identifier.

## BACnet IP Network Addressing

The BACnet/Internet Protocol (BACnet/IP) address of the chiller unit controller in a BACnet/IP network consists of the four-octet Internet Protocol address followed by the two-octet UDP (User Datagram Protocol) port number. The BACnet/IP address is a six-octet value analogous to a Media Access Control (MAC) address. The IP address portion of the BACnet/IP address must be unique in the BACnet/IP network segment. The default UDP port number in the chiller unit controller is 47808 (BAC0 in hexadecimal).

The device object of the chiller unit controller contains a Given Internet Protocol Subnet Mask (Default is 255.255.255.0) and a default Given IP address of 192.168.1.10. The controller also supports DHCP (Dynamic Host Configuration Protocol) IP addressing, which can be enabled using the unit HMI. The chiller HMI can be used to configure the BACnet/IP addressing.

The chiller unit controller can be incorporated into a BACnet/IP network dedicated to BACnet devices only or an Ethernet network shared with BACnet devices and other devices.

## Shared Ethernet Networks

Integrating the chiller unit controller into a shared Ethernet LAN requires close cooperation with the network administrator of the shared Ethernet network. First, verify whether DHCP should or should not be enabled. If not, obtain the IP Subnet Mask of the shared network from the network administrator. Then, obtain static IP Addresses for all chiller unit controllers being integrated into the shared network. Finally, obtain the address of an IP Router to use for sending IP messages to and from the BACnet IP subnets. Once all information is determined, refer to the “Setting Unit Controller Communication Parameters” section for further instruction.

## BACnet MS/TP Network Addressing

The BACnet MS/TP MAC address of the chiller unit controller in a BACnet Master Slave/Token Passing (MS/TP) is set using the chiller HMI.

The BAS module power must be cycled for the new address to take effect.

The default data transmission rate is set to 38,400 bps (baud). This rate can be changed to 19,200 or 76,800 with the HMI. Refer to the “Setting Unit Controller Communication Parameters” section.

## Modbus Networks

The chiller unit controller can be configured in an interoperable Modbus network. The controller must have the corresponding Modbus Communication Module installed.

The chiller unit controller conforms to the published Modbus standards. Refer to [www.Modbus.org](http://www.Modbus.org) for more information.

## Valid Function Codes

The chiller unit controller supports the eight Modbus public function codes shown in Table 3. However, the chiller unit controller contains only Holding Registers (4xxxx), so not all function codes would be used.

**Table 3: Valid Function Codes**

Function Code	Description	Definition
01 (0x01)	Read Coil Status	Reads the On/Off status of discrete outputs
02 (0x02)	Read Input Status	Reads the On/Off status of discrete inputs
03 (0x03)	Read Holding Registers	Reads one to approximately 125 contiguous input registers in a remote device
04 (0x04)	Read Input Registers	Reads the contents of input registers
05 (0x05)	Force Single Coil	Forces a single coil to either On or Off
06 (0x06)	Write Single Register	Writes a single Holding Register to a remote device
15 (0x0F)	Write Multiple Coils	Forces each coil in a sequence of coils to either On or Off
16 (0x10)	Write Multiple Registers	Writes a block of one to approximately 120 contiguous registers in a remote device

## Valid Error Codes

The chiller unit controller supports all exception codes. See [Table 4](#) for a description of valid error codes.

**Table 4: Valid Error Codes**

Error Codes	Description	Definition
01	Illegal Function	The function code received in the query is not an allowable action for the server (or slave)
02	Illegal Data Address	The data address received in the query is not an allowable address for the server (or slave)
03	Illegal Data Value	A value contained in the query data field is not an allowable value for server (or slave)
04	Slave Device Failure	An unrecoverable error occurred while the server (or slave) was attempting to perform the requested action
05	Acknowledged	The server (or slave) has accepted and is processing the request
06	Slave Device Busy	The server (or slave) is busy processing a command. The client (or master) should retransmit when the server (or slave) is free
08	Memory Parity Error	The server (or slave) attempted to read record file, but detected a parity error in the memory. The client (or master) can retry the request, but service may be required on the server (or slave) device
0A	Gateway Path Unavailable	The gateway may be configured incorrectly or overloaded
0B	Gateway Target Device Failed to Respond	No response from the target device

## Modbus Addressing

Each function code implies access to a specific Modbus reference set. Therefore, the leading digit is not included in the address field of a Modbus message. The Modbus Communication Module supports zero-based addressing. For example, Holding Register 40003 is addressed as 0002 in a Modbus message.

## Modbus Data Point

Each data point accessible from a Modbus network is described with a table that gives the data type and Holding Register. If the data point represents an enumerated variable, the enumerations are also listed.

When a variable spans multiple Holding Registers, it is important to know how the data is represented in those Holding Registers.

The following example shows Compressor Run Hours. Circuit 1, Compressor 1 run hours are located at Holding Registers 74-75 (40074-40075). If the operating hours are 99900 (0x0001 0x863C), the registers will read as follows:

- 74 = 0x0001
- 75 = 0x863C

For strings, the interpretation differs. In this case, each Holding Register can contain two characters. If a string spans multiple registers, the first register (lowest register number) contains the two left-most characters of the string. Since the chiller unit controller only supports Modbus RTU, use the ASCII Conversion Table in Appendix B to translate the numerical data to their corresponding ASCII characters.

## Example Data Point: Chiller On/Off

This output data point indicates the current state of the chiller. The OFF state is represented by state = FALSE and value = 0. The other discrete states are represented by state = TRUE and value > 0.

Data Type	Holding Register	Measurement	Units	Valid Range
RO Holding Register	8	Chiller State	NA	0 = Off 1 = On

## Data Type

Data is represented as either single-bit elements or 16-bit elements. A single-bit element is referred to as a Discrete Input when it refers to read-only data and as a Coil when it refers to read-write data. A 16-bit element is referred to as an Input Register when it refers to read-only data, and as a Holding Register when it refers to read-write data. All the Modbus registers defined in the chiller unit controller are 16-bit Holding Registers. Some are read only (RO) and some are read-write (RW).

## Holding Register

There are up to 65,536 elements of each data type in a Modbus device. Data elements are numbered from 1 to 65,536 in each type. Data elements are addressed with an index in the range from 0 to 65,535. The index is not the address of the data element in the unit controller memory, but instead it is used in Modbus PDUs to specify the location of the data in the unit controller. This means, for example, that data element number 1 (i.e., Holding Register 40001) is addressed using index 0 in the PDU.

In addition, the function code field portion of the message already specifies a “Holding Register” operation. Therefore the ‘4xxxx’ reference is implicit. As such, this document represents the Holding Registers without the implicit 4xxxx. For example, Holding Register 8 is actually Holding Register 40008.

### ***Valid Range***

Some properties are standard data types and some are enumerated sets. If the property value represents a range of values (e.g. temperature or pressure) that range of values is shown. If the property value is an enumerated set, all enumerated values and corresponding meaning are shown as well.

## **Configuring the Unit Controller**

The Unit Controller is ready to operate with the default values of the various parameters set at the factory. Default values may be changed with the unit's HMI or via the network.

For an AGZ-F chiller to use the Network Enable, Cool Setpoint, Ice Setpoint, Mode Setpoint and Capacity Limit Setpoint commands from the BAS, "Control Source" must be set to "BAS" at the unit HMI. See the chiller unit controller operation manual for unit settings and IM 1283 for network parameter settings ([www.DaikinApplied.com](http://www.DaikinApplied.com)).

For a WMC-E or WMT chiller to use the Network Enable, Cool or Heat Setpoint, Mode Setpoint and Capacity Limit Setpoint commands from the BAS, "Control Source" must be set to "BAS" at the unit HMI. See the chiller unit controller operation manual for unit settings and IM 1283 for network parameter settings ([www.DaikinApplied.com](http://www.DaikinApplied.com)).

# Comprehensive Data Tables

## Network Parameters

The following section defines the network parameters, or data points, available to the BAS from the chiller unit controller. [Table 5](#) lists all BACnet objects and Modbus registers supported for each chiller model type.

**Table 5: Data Points by Chiller Model**

Data Point	AGZ-F	WMT	WMC-E
Active Capacity Limit (Output)	X	X	X
Active Setpoint	X	X	X
Actual Capacity	X	X	X
Alarm Digital Output	X	X	X
Alarm Index Fault	X	X	X
Alarm Index Problem	X		X
Alarm Index Warning	X	X	X
Alarm Module ID Fault	X	X	X
Alarm Module ID Problem	X		X
Alarm Module ID Warning	X	X	X
Alarm Module Payload Fault	X	X	X
Alarm Module Payload Problem	X		X
Alarm Module Payload Warning	X	X	X
Alarm ModuleType Fault	X	X	X
Alarm ModuleType Problem	X		X
Alarm ModuleType Warning	X	X	X
Capacity Limit Setpoint - Network	X	X	X
Chiller Capacity Limited	X	X	X
Chiller Enable Output	X	X	X
Chiller Enable Setpoint	X	X	X
Chiller Local/Network	X	X	X
Chiller Mode Output	X	X	X
Chiller Mode Setpoint - Network	X	X	X
Chiller On/Off	X	X	X
Chiller Status	X	X	X
Clear Alarm - Network	X	X	X
Compressor Current		X	X
Compressor Percent RLA		X	X
Compressor Power		X	X
Compressor Run Hours	X	X	X
Compressor Starts	X	X	X
Compressor Unavailable (BACnet Only)		X	X
Compressor Voltage		X	X
Condenser Entering Fluid Temperature		X	X
Condenser Flow Rate (Field-Supplied Flow Meter)		X	X
Condenser Flow Switch Status		X	X
Condenser Leaving Fluid Temperature		X	X
Condenser Pump Run Hours		X	X
Condenser Pump Status		X	X
Condenser Refrigerant Pressure	X	X	X
Condenser Saturated Refrigerant Temperature	X	X	X
Cool Setpoint - Network	X	X	X

Data Point	AGZ-F	WMT	WMC-E
Discharge Refrigerant Pressure		X	X
Discharge Refrigerant Temperature	X	X	X
Discharge Saturated Refrigerant Temperature		X	X
Evaporator Entering Fluid Temperature	X	X	X
Evaporator Flow Rate (Field-Supplied Flow Meter)		X	X
Evaporator Flow Switch Status	X	X	X
Evaporator Leaving Fluid Temperature	X	X	X
Evaporator Pump Run Hours	X	X	X
Evaporator Pump Status	X	X	X
Evaporator Refrigerant Pressure	X	X	X
Evaporator Saturated Refrigerant Temperature	X	X	X
Heat Recovery Entering Fluid Temperature			X
Heat Recovery Leaving Fluid Temperature			X
Heat Setpoint - Network			X
Ice Setpoint - Network	X		
Liquid Line Refrigerant Temperature		X	X
Outdoor Air Temperature	X		
Refrigerant Type	X	X	X
Run Enabled	X	X	X
Suction Refrigerant Pressure		X	X
Suction Refrigerant Temperature	X	X	X
Suction Saturated Refrigerant Temperature		X	X
Units	X	X	X

## BACnet Network Objects

This section describes the data that is available to the BAS via the BACnet network. Each BACnet object may or may not be available on the unit HMI. If it is available, the keypad/display menu shows one path where the object appears, but note that it may also be available on more than one keypad menu. Table 6 through Table 10 contain the relevant information needed to integrate the chiller unit controller into the BACnet network. The tables are organized by Analog Inputs, Analog Values, Binary Inputs, Binary Values, and Multi-State Values. The parameters are listed alphabetically by point name within each table.

**Table 6: BACnet Analog Inputs**

Point Name	Object Type/Instance	Read/Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Compressor Current</b>					
Circuit 1 Compressor 1	AI:9	R	C1Comp1Current	Amp range varies by chiller model Default: NA	The average current of the compressor motor.
Circuit 1 Compressor 2	AI:10		C1Comp2Current		
<b>Compressor Power</b>					
Circuit 1 Compressor 1	AI:45	R	C1Comp1Kilowatts	0 – 3500 kilowatts Default: NA	The current power of the compressor motor.
Circuit 1 Compressor 2	AI:46		C1Comp2Kilowatts		
<b>Compressor Voltage</b>					
Circuit 1 Compressor 1	AI:27	R	C1Comp1Voltage	0 – 15000 VAC Default: NA	The average voltage of the compressor motor.
Circuit 1 Compressor 2	AI:28		C1Comp2Voltage		
<b>Condenser Entering Fluid Temperature</b>					
	AI:3	R	EntCondWaterTemp	-40 – 230°F -40 – 110°C Default: NA	The current temperature of the fluid entering the condenser.
<b>Condenser Flow Rate</b>					
	AI:147	R	CondWaterFlowRate	0-65,535 GPM 0-4134.6 L/S Default: NA	The current fluid flow rate for the condenser (Field-Supplied Flow Meter).
<b>Condenser Leaving Fluid Temperature</b>					
	AI:4	R	LvgCondWaterTemp	-40 – 230°F -40 – 110°C Default: NA	The current temperature of the fluid leaving the condenser.
<b>Condenser Refrigerant Pressure</b>					
Circuit 1	AI:99	R	Cond1RefPressure	-14.5 to 43.51 Psi (R1233zd(E)) -100 to 300 kPa (R1233zd(E)) 0-700 Psi (R32) 0-4826 kPa (R32) Default: NA	Indicates the current condenser refrigerant pressure for the circuit.
Circuit 2	AI:100	R	Cond2RefPressure		
<b>Discharge Refrigerant Pressure</b>					
Circuit 1 Compressor 1	AI:81	R	C1Comp1DischRefPressure	-14.5 to 43.51 Psi (R1233zd(E)) -100 to 300 kPa (R1233zd(E)) Default: NA	The current discharge refrigerant pressure for the compressor.
Circuit 1 Compressor 2	AI:82		C1Comp2DischRefPressure		

Point Name	Object Type/Instance	Read/Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Discharge Refrigerant Temperature</b>					
Circuit 1 Compressor 1	AI:63	R	C1Comp1Discharge-Temp	-40 – 249.8°F -40 – 121°C Default: NA	Indicates the current discharge refrigerant temperature for the circuit or compressor.  NOTE: On AGZ-F, there is a single sensor per circuit.
Circuit 1 Compressor 2	AI:64		C1Comp2Discharge-Temp		
Circuit 2 Compressor 1	AI:66		C2Comp1Discharge-Temp		
<b>Evaporator Entering Fluid Temperature</b>					
	AI:1	R	EntEvapWaterTemp	-40 – 230°F -40 – 110°C Default: NA	The temperature of the fluid entering the evaporator.
<b>Evaporator Flow Rate</b>					
	AI:148	R	EvapWaterFlowRate	0-65,535 GPM 0-4134.6 L/S Default: NA	The current fluid flow rate for the evaporator (Field-Supplied Flow Meter).
<b>Evaporator Leaving Fluid Temperature</b>					
	AI:2	R	LvgEvapWaterTempUnit	-40 – 230°F -40 – 110°C Default: NA	The current temperature of the fluid leaving the evaporator.
<b>Evaporator Refrigerant Pressure</b>					
Circuit 1	AI:141	R	C1EvapRefPressure	-14.5 to 21.76 Psi (R1233zd(E)) -100 to 150 kPa (R1233zd(E)) 0-350 Psi (R32) 0-2413 kPa (R32) Default: NA	Indicates the current evaporator refrigerant pressure for the circuit.
Circuit 2	AI:142		C2EvapRefPressure		
<b>Heat Recovery Entering Fluid Temperature</b>					
	AI:177	R	HeatRecEntWaterTemp	-40 – 230°F -40 – 110°C	The heat recovery entering fluid temperature
<b>Heat Recovery Leaving Fluid Temperature</b>					
	AI:150	R	HeatRecLvgWaterTemp	-40 – 230°F -40 – 110°C	The heat recovery leaving fluid temperature
<b>Liquid Line Refrigerant Temperature</b>					
Circuit 1	AI:218	R	C1LiqLineRefTemp	-40°–230°F -40°–110°C Default: NA	The current liquid line refrigerant temperature.
<b>Outdoor Air Temperature</b>					
	AI:5	R	OutdoorAirTemp	-40 – 230°F -40 – 110°C Default: NA	Indicates the current outdoor air temperature.
<b>Suction Refrigerant Pressure</b>					
Circuit 1 Compressor 1	AI:123	R	C1Comp1SuctionPressure	-14.5 to 21.76 Psi (R1233zd(E)) -100 to 150 kPa (R1233zd(E)) Default: NA	The current suction refrigerant pressure for the compressor.
Circuit 1 Compressor 2	AI:124		C1Comp2SuctionPressure		

Point Name	Object Type/Instance	Read/Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Suction Refrigerant Temperature</b>					
Circuit 1 Compressor 1	AI:105	R	C1Comp1SuctionTemp	-40 – 230°F -40 – 110°C Default: NA	Indicates the current suction refrigerant temperature for the circuit or compressor.  NOTE: On AGZ-F, there is a single sensor per circuit.
Circuit 1 Compressor 2	AI:106		C1Comp2SuctionTemp		
Circuit 1	AI:224		C1SuctionTemperature		
Circuit 2	AI:225		C2SuctionTemperature		

Table 7: BACnet Analog Values

Point Name	Object Type/Instance	Read/Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Active Capacity Limit Output</b>					
	AV:1	R	ActiveCapacityLimit	0 – 100% Default: NA	Measures of the ratio of operating capacity limit to full capacity expressed as a percentage. This value is the lowest of all limits specified by the operator, analog Demand Limit input, or Network Capacity Limit Setpoint.
<b>Active Setpoint</b>					
	AV:5	R	ActiveLvgWaterTarget	14.9 - 80.0°F, -9.5 – 26.67°C Default: NA	Indicates the current setpoint used to control the chiller. The setpoint that is used is based on the operating mode (Cool or Ice) of the chiller and any "LWT reset" functions that are in effect. See Chiller Mode Output and Chiller Mode Setpoint – Network. There are two possible setpoints: Cool Setpoint – Network and Ice Setpoint – Network. Refer to unit IOM for valid, model-specific setpoints.
<b>Actual Capacity</b>					
	AV:2	R	ChillerCapacity	0 – 100% Default: NA	Indicates the percent of maximum capacity the chiller is producing under the present operating conditions. At 100%, the chiller may be producing more or less than its nominal rating due to variations in operating conditions.
<b>Alarm Index</b>					
	AV:901	R	AVFaultAlarm		See BACnet Alarm Indices section for additional information.
	AV:900		AVProblemAlarm		
	AV:902		AVWarningAlarm		
<b>Alarm Module ID</b>					
	AV:910	R	AVFaultModID		See BACnet Alarm Module ID section for additional information.
	AV:907		AVProblemModID		
	AV:913		AVWarningModID		
<b>Alarm Module Payload</b>					
	AV:911	R	AVFaultModPayload		See BACnet Alarm Module Payload section for additional information.
	AV:908		AVProblemModPayload		
	AV:914		AVWarningModPayload		
<b>Alarm Module Type</b>					
	AV:909	R	AVFaultModType		See BACnet Alarm Type section for additional information.
	AV:906		AVProblemModType		
	AV:912		AVWarningModType		

Point Name	Object Type/ Instance	Read/ Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Capacity Limit Setpoint - Network</b>					
	AV:3	W	NetworkCapacityLimitPct	0 – 100% Default: 100%	Sets the maximum capacity level of the chiller. This level may be adjusted, but not above the factory-specified limit. The unit controller only uses this value if Control Source is set to BAS. Control Source can only be changed using the unit HMI. Available Modes can also be found on the HMI.
<b>Compressor Percent RLA</b>					
Circuit 1 Compressor 1	AV:8	R	C1Comp1MotorCurrentPercent	0-115% Default: 0	The current percent RLA for the compressor motor of the compressor.
Circuit 1 Compressor 2	AV:9		C1Comp2MotorCurrentPercent		
<b>Compressor Run Hours</b>					
Circuit 1 Compressor 1	AV:74	R	C1Comp1Hours	0 –999,999 Default: NA	The number of hours that the compressor motor has been turned on.
Circuit 1 Compressor 2	AV:75		C1Comp2Hours		
Circuit 1 Compressor 3	AV:76		C1Comp3Hours		
Circuit 2 Compressor 1	AV:77		C2Comp1Hours		
Circuit 2 Compressor 2	AV:78		C2Comp2Hours		
Circuit 2 Compressor 3	AV:79		C2Comp3Hours		
<b>Compressor Starts</b>					
Circuit 1 Compressor 1	AV:92	R	C1Comp1Starts	0 –999,999 Default: NA	The number of times the compressor motor has been started.
Circuit 1 Compressor 2	AV:93		C1Comp2Starts		
Circuit 1 Compressor 3	AV:94		C1Comp3Starts		
Circuit 2 Compressor 1	AV:95		C2Comp1Starts		
Circuit 2 Compressor 2	AV:96		C2Comp2Starts		
Circuit 2 Compressor 3	AV:97		C2Comp3Starts		
<b>Condenser Pump Run Hours</b>					
Condenser Pump 1	AV:110	R	CondPump1RunHours	0 –999,999 Default: NA	The number of hours that the pump motor has been turned on.
Condenser Pump 2	AV:111		CondPump2RunHours		
<b>Condenser Saturated Refrigerant Temperature</b>					
Circuit 1	AV:44	R	Cond1SatRefTemp	-40 – 230°F	Indicates the current saturated refrigerant temperature of the condenser.
Circuit 2	AV:45		Cond2SatRefTemp	-40 – 110°C Default: NA	
<b>Cool Setpoint - Network</b>					
	AV:4	W	NetworkCoolTempSetpoint	WMT: 36.0 - 80.0°F, 2.22 - 26.67°C AGZ-F: 14.9 - 70.0°F, -9.5 - 21.1°C Low limit = 39.9°F w/o glycol, 14.9°F w/ glycol Default = 44.0°F	Changes the Cooling setpoint from the network. It sets the temperature of the Leaving Chilled Fluid when the chiller is operating in the Cooling Mode. It cannot be set below the local Cool Setpoint. The unit controller only uses this value if Control Source is set to BAS. Control Source can only be changed using the unit HMI. Available Modes can also be found on the HMI.
<b>Discharge Saturated Refrigerant Temperature</b>					
Circuit 1 Compressor 1	AV:26	R	C1Comp1DischSatRefTemp	-40 – 230°F	The current discharge saturated refrigerant temperature for the compressor.
Circuit 1 Compressor 2	AV:27		C1Comp2DischSatRefTemp	-40 – 110°C Default: NA	

Point Name	Object Type/ Instance	Read/ Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Evaporator Pump Run Hours</b>					
Evaporator Pump 1	AV:112	R	EvapPump1OperHours	0 – 999,999	Indicates the number of hours the pump motor has been turned on.
Evaporator Pump 2	AV:113		EvapPump2OperHours	Default: NA	
<b>Evaporator Saturated Refrigerant Temperature</b>					
Circuit 1	AV:68	R	C1EvapSatRefTemp	-40 – 230°F	Indicates the current saturated refrigerant temperature of the evaporator.
Circuit 2	AV:69		C2EvapSatRefTemp	-40 – 110°C Default: NA	
<b>Ice Setpoint - Network</b>					
	AV:7	W	NetworkIceTempSetpoint	AGZ-F: 14.9 – 39.9°F, -9.5 – 4.4°C Default = 24.98°F	Changes the Ice setpoint from the network. It sets the temperature of the Leaving Chilled Fluid when the chiller is operating in the Ice Mode. The unit controller only uses this variable if the Control Source is set to "BAS" at the unit HMI.
<b>Heat Setpoint - Network</b>					
	AV:6	W	NetworkHeatTempSetpoint	100 – 150°F 37.7 – 65.5°C Default = Varies by Model	Changes the Heating setpoint in from the network. It sets the temperature of the Leaving Condenser Fluid when the chiller is operating in Heating Mode. It cannot be set above the local Heat Setpoint. The unit controller only uses this value if the Control Source is set to BAS. Control Source can only be changed using the unit HMI. Available Modes can also be found on the HMI.
<b>Suction Saturated Refrigerant Temperature</b>					
Circuit 1 Compressor 1	AV:50	R	C1Comp1SuctSatTemp	-40 – 230°F	The current suction saturated refrigerant temperature for the compressor.
Circuit 1 Compressor 2	AV:51		C1Comp2SuctSatTemp	-40 – 110°C Default: NA	

**Table 8: BACnet Binary Values**

Point Name	Object Type/ Instance	Read/Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Chiller Enable Setpoint</b>					
	BV:2	W	ChillerEnableStp	0 = Disable (Inactive) 1 = Enable Default: 0 = Disabled	Disables or enables chiller operation over the network. Setting this variable to Enable does not start the chiller. It only allows the chiller to start if other operating conditions are satisfied. The unit controller only uses this value if Control Source is set to BAS. Control Source can only be changed using the unit HMI. Available Modes can also be found on the HMI.
<b>Clear Alarm - Network</b>					
	BV:8	W	ClearAlarm	0 = Normal 1 = Clear Alarm	Clears all active alarms. Many alarms are automatically clearing alarms. Refer to the respective chiller Installation, Operation and Maintenance Manual (IOM), available on www.DaikinApplied.com, for details on auto-clearing alarms.

Table 9: BACnet Binary Inputs

Point Name	Object Type/ Instance	Read/Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Alarm Digital Output</b>					
	Bl:10	R	AlarmDigitalOutput	0 = No Alarm 1 = Alarm	Indicates whether an alarm condition has occurred. This object must be polled for alarm indication.
<b>Chiller Capacity Limited</b>					
	Bl:6	R	ChillerLimited	0 = Not Limited 1 = Limited	Indicates whether conditions may exist that prevent the chiller from reaching full capacity.
<b>Chiller Enable Output</b>					
	Bl:7	R	ChillerEnableOutput	0 = Disable 1 = Enable	Indicates if operation of the chiller is disabled or enabled. The chiller is allowed to run if enabled and not allowed to run if disabled.
<b>Chiller Local/Network</b>					
	Bl:3	R	ChillerLocalRemote	0 = Network 1 = Local	Indicates whether the chiller is in local control or allowed to be controlled remotely over the network. The value can only be changed locally from the unit controller keypad/display. The values from the following variables are ignored in the chiller application if this variable is set to Local (1): <ul style="list-style-type: none"> <li>• Chiller Enable Setpoint</li> <li>• Chiller Mode Setpoint – Network</li> <li>• Cool Setpoint Network</li> <li>• Capacity Limit Setpoint</li> <li>• Clear Alarm Network</li> <li>• Ice Setpoint Network</li> </ul>
<b>Chiller On/Off</b>					
	Bl:4	R	UnitOnOff	0 = Chiller Off 1 = Chiller On	The current state of the chiller.
<b>Compressor Unavailable</b>					
Circuit 1 Compressor 1	Bl:163	R	C1Cmp1Unavailable	0 = Available 1 = Unavailable Default: NA	Indicates whether the compressor is available to run.
Circuit 1 Compressor 2	Bl:164	R	C1Cmp2Unavailable		
<b>Condenser Flow Switch Status</b>					
	Bl:1	R	CondWaterFlowStatus	0 = No Flow 1 = Flow	The status of the fluid flowing through the condenser.
<b>Condenser Pump Status</b>					
Pump 1	Bl:11	R	CondPump1State	0 = Pump Off Request 1 = Pump On Request	Indicates if the pump has been commanded ON or OFF.
Pump 2	Bl:12		CondPump2State		
<b>Evaporator Flow Switch Status</b>					
	Bl:2	R	EvapWaterFlowStatus	0 = No Flow 1 = Flow	The status of the fluid flowing through the evaporator.
<b>Evaporator Pump Status</b>					
Pump 1	Bl:8	R	EvapPump1State	0 = Pump Off Request 1 = Pump On Request	Indicates if the pump has been commanded ON or OFF.
Pump 2	Bl:9		EvapPump2State		
<b>Run Enabled</b>					
	Bl:5	R	RunEnabled	0 = Off 1 = Run Allowed Default: NA	The running mode of the chiller. Run Enabled indicates that the chiller can start if operating conditions are met.

**Table 10: BACnet Multi-State Values**

Point Name	Object Type/Instance	Read/Write Access	BACnet Object Name	Range/Default (In Units)	Description
<b>Chiller Mode Output</b>					
	MSV:2	R	ActiveMode	1 = ICE 2 = COOL 3 = HEAT 4 = COOL/HEAT RECOVERY Default: 2 = COOL	The current operating mode of the chiller.
<b>Chiller Mode Setpoint - Network</b>					
	MSV:3	R/W	ChillerOperationMode	1 = ICE 2 = COOL 3 = HEAT 4 = COOL/HEAT RECOVERY Default: 2 = COOL	Changes the operating mode of the chiller and provides the ability for another node on the network to place a chiller in another mode. The unit controller only uses this value if Control Source is set to BAS. Control Source can only be changed using the unit HMI. Available Modes can also be found on the HMI.
<b>Chiller Status</b>					
	MSV:1	R	UnitStatus	1 = OFF 2 = START 3 = RUN 4 = PRESHUTDOWN 5 = SERVICE	The unit status of the chiller.
<b>Refrigerant Type</b>					
	MSV:7	R	RefrigerantType	1 = R22 2 = R134a 3 = R407c 4 = R410a 5 = R32 6 = R454C 7 = R513A 8 = R515B 9 = R1233zd(E) 10 = R1234ze(E)	Indicates the type of refrigerant used in the chiller.
<b>Units</b>					
	MSV:4	R/W	Units	1 = Metric 2 = English Default: English (2)	Sets the type of units (English or Metric) sent from the chiller unit controller to the BACnet network.

## Modbus Register Mapping

The Modbus Communication Module supports zero-based addressing. For example, Holding Register 40002 is addressed as 0001 in a Modbus message. The Holding Registers shown in Table 11 through Table 13 assume 4xxxx addressing. For example, Holding Register 40001 is shown as 1.

When a variable spans multiple Holding Registers, it is important to know how the data is represented in those Holding Registers.

The following example shows Compressor Run Hours. Circuit 1, Compressor 1 run hours are located at Holding Registers 74-75 (40074-40075). If the operating hours are 99900 (0x0001 0x863C), the registers will read as follows:

74 = 0x0001  
75 = 0x863C

**Table 11: Chiller Data Points**

Chiller Data Point	Holding Register	Data Type	Read/Write Access	Range/Default (In Units)	Description
<b>Active Capacity Limit Output</b>					
	14	RO Holding Register	R	0 – 100% × 10 Default: NA	A measure of the ratio of operating capacity limit to full capacity expressed in percent. This value is the lowest of all limits specified by the operator, analog Demand Limit input, or Network Capacity Limit Setpoint.
<b>Active Setpoint</b>					
	12	RO Holding Register	R	14.9 - 80.0°F × 10 -9.5 – 26.67°C × 10 Default: NA Refer to unit IOM for valid, model-specific setpoints.	Indicates the current setpoint used to control the chiller. Based on the operating mode of the chiller, this value is derived from the Cooling Setpoint or Ice Setpoint. See Cool Setpoint - Network and Ice Setpoint - Network as well as Chiller Mode Output and Chiller Mode Setpoint - Network.
<b>Actual Capacity</b>					
	13	RO Holding Register	R	0 – 100% × 10 Default: NA	Indicates the percent of maximum capacity the chiller is producing under the present operating conditions. At 100%, the chiller may be producing more or less than its nominal rating due to variations in operating conditions.
<b>Alarm Digital Output</b>					
	5	RO Holding Register	R	0=No Alarm 1=Alarm Default: NA	Indicates whether an alarm condition has occurred. This variable must be polled for alarm indication.
<b>Alarm Index</b>					
Fault	30	RO Holding Register	R		See Modbus Alarm Indices section for additional information.
Problem	29				
Warning	28				
<b>Alarm Module ID</b>					
Fault	2008	RO Holding Register	R		See Modbus Alarm Module ID section for additional information.
Problem	2005				
Warning	2002				
<b>Alarm Module Payload</b>					
Fault	2009	RO Holding Register	R		See Modbus Alarm Module Payload section for additional information.
Problem	2006				
Warning	2003				
<b>Alarm Module Type</b>					
Fault	2007	RO Holding Register	R		See Modbus Alarm Module Type section for additional information.
Problem	2004				
Warning	2001				
<b>Capacity Limit Setpoint - Network</b>					
	38	RW Holding Register	R/W	0 – 100% × 10 Default: 100% × 10	Sets the maximum capacity level of the chiller. This level may be adjusted via an operator workstation or other network device, but cannot be adjusted above a factory-specified limit. The unit controller only uses the value of this register if Control Source is set to BAS. Control Source can only be changed using the unit HMI.

Chiller Data Point	Holding Register	Data Type	Read/Write Access	Range/Default (In Units)	Description
<b>Chiller Capacity Limited</b>					
	4	RO Holding Register	R	0=Not Limited 1=Limited Default: NA	Indicates whether conditions may exist that prevent the chiller from reaching full capacity.
<b>Chiller Enable Output</b>					
	2	RO Holding Register	R	0=Disable 1=Enable Default: 0=Disabled	Indicates if operation of the chiller is disabled or enabled. The chiller is allowed to run if enabled and not allowed to run if disabled.
<b>Chiller Enable Setpoint</b>					
	9	RW Holding Register	R/W	0=Disable 1=Enable 2=NULL Default: Null	Disables or enables chiller operation over the network. Setting this variable to Enable does not start the chiller. It only allows the chiller to start if other operating conditions are satisfied. The unit controller only uses this variable if Control Source is set to BAS. Control Source can only be changed using the unit HMI.
<b>Chiller Local/Network</b>					
	1	RO Holding Register	R	0=Remote 1=Local Default: Null	Indicates whether the chiller is in local control or allowed to be controlled remotely over the network. The value can only be changed locally. The values from the following variables are ignored in the chiller application if this variable is set to Local (1): <ul style="list-style-type: none"> <li>• Chiller Mode Setpoint – Network</li> <li>• Cool Setpoint Network</li> <li>• Ice Setpoint Network</li> <li>• Capacity Limit Setpoint</li> <li>• Clear Alarm Network</li> </ul>
<b>Chiller Mode Output</b>					
	11	RO Holding Register	R	1=Ice 2=Cool 3=Heat 4=Cool/Heat Recovery Default: NA	Indicates the current operating mode of the chiller.
<b>Chiller Mode Setpoint - Network</b>					
	34	RW Holding Register	R/W	1=Ice 2=Cool 3=Heat 4=Cool/Heat Recovery Default: 2=Cool	Changes the operating mode of the chiller. The unit controller only uses the value of this register if Control Source is set to BAS. Control Source can only be changed using the unit HMI. Available Modes can also be found on the unit HMI. A value of Null causes the chiller to run in the Cool mode if nothing else is writing to this point.
<b>Chiller On/Off</b>					
	8	RO Holding Register	R	0=Off 1=On	Indicates the current state of the chiller. The OFF state is represented by State = FALSE and Value = 0. The other discrete states are represented by State = TRUE and Value > 0.
<b>Chiller Status</b>					
	15	RO Holding Register	R	1=Off 2=Start 3=Run 4=Pre Shutdown 5=Service Default: Determined by current state of chiller	Indicates the status of the chiller.
<b>Clear Alarm - Network</b>					
	10	RW Holding Register	R/W	0=Normal 1=Clear Alarms 2=NULL Default: Null	Clears all active alarms. Many alarms are automatically clearing alarms. Refer to the respective chiller Installation, Operation and Maintenance Manual (IOM), available on <a href="http://www.DaikinApplied.com">www.DaikinApplied.com</a> , for details on auto-clearing alarms.
<b>Condenser Entering Fluid Temperature</b>					
	19	RO Holding Register	R	-40° – 230°F × 10 -40° – 110°C × 10 Default: NA	Indicates the current temperature of the fluid entering the condenser.

Chiller Data Point	Holding Register	Data Type	Read/Write Access	Range/Default (In Units)	Description
<b>Condenser Flow Rate</b>					
	21	RO Holding Register	R	0 – 65,535 GPM 0 – 4134.6 L/S Default: NA	Indicates the current fluid flow rate for the condenser. (Field-Supplied Flow Meter)
<b>Condenser Flow Switch Status</b>					
	7	RO Holding Register	R	0=OFF 1=ON Default: NA	Indicates the status of the fluid flowing through the condenser.
<b>Condenser Leaving Fluid Temperature</b>					
	20	RO Holding Register	R	-40° – 230°F × 10 -40° – 110°C × 10 Default: NA	Indicates the current temperature of the fluid leaving the condenser.
<b>Cool Setpoint - Network</b>					
	35	RW Holding Register	R/W	WMT: 36.0 - 80.0°F × 10, 2.22 - 26.67°C × 10 AGZ-F: 14.9 - 70.0°F × 10, -9.5 – 21.1°C × 10 Low limit = 39.9°F w/o glycol, 14.9°F w/ glycol Default = 44.0°F	Changes the Cooling setpoint from the network. It sets the temperature of the Leaving Chilled Fluid setpoint when the chiller is operating in the Cooling Mode. The unit controller only uses the value of this register if Control Source is set to BAS. Control Source can only be changed using the unit HMI.
<b>Evaporator Entering Fluid Temperature</b>					
	16	RO Holding Register	R	-40 – 230°F × 10 -40 – 110°C × 10 Default: NA	Indicates the current temperature of the fluid entering the evaporator.
<b>Evaporator Flow Rate</b>					
	18	RO Holding Register	R	0-65,535 GPM 0-4134.6 L/S Default: NA	Indicates the current fluid flow rate for the evaporator. (Field-Supplied Flow Meter)
<b>Evaporator Flow Switch Status</b>					
	6	RO Holding Register	R	0=No Flow 1=Flow Default: NA	Indicates the status of the fluid flowing through the evaporator.
<b>Evaporator Leaving Fluid Temperature</b>					
	17	RO Holding Register	R	-40 – 230°F × 10 -40 – 110°C × 10 Default: NA	Indicates the current temperature of the fluid leaving the evaporator.
<b>Heat Recovery Entering Fluid Temperature</b>					
	22	RO Holding Register	R	-40 – 230°F × 10 -40 – 110°C × 10 Default: NA	The heat recovery entering fluid temperature.
<b>Heat Recovery Leaving Fluid Temperature</b>					
	23	RO Holding Register	R	-40 – 230°F × 10 -40 – 110°C × 10 Default: NA	The heat recovery leaving fluid temperature.
<b>Heat Setpoint - Network</b>					
	37	RO Holding Register	R/W	100 – 150°F × 10 37.7 – 65.5°C × 10 Default: Varies by model	Changes the Heating setpoint from the network. It sets the temperature of the Leaving Condenser Fluid setpoint when the chiller is operating in the Heating Mode. The unit controller only uses the value of this register if Control Source is set to BAS. Control Source can only be changed using the unit HMI.
<b>Ice Setpoint - Network</b>					
	36	RW Holding Register	R/W	AGZ-F: 14.9 – 39.9°F × 10 -9.5 – 4.4°C × 10 Default = 24.98°F	Changes the Ice setpoint from the network. It sets the temperature of the Leaving Chilled Fluid when the chiller is operating in the Ice Mode. The unit controller only uses this variable if Control Source is set to BAS. Control Source can only be changed using the unit HMI.

Chiller Data Point	Holding Register	Data Type	Read/Write Access	Range/Default (In Units)	Description
<b>Outdoor Air Temperature</b>					
	24	RO Holding Register	R	-40 – 230°F × 10 -40 – 110°C × 10 Default: NA	The current outdoor air temperature.
<b>Refrigerant Type</b>					
	1606	RO Holding Register	R	1=R22 2=R134a 3=R407c 4=R410a 5= R32 6=R454C 7=R513A 8=R515B 9=R1233zd(E) 10=R1234ze(E)	Indicates the type of refrigerant used in the chiller.
<b>Run Enabled</b>					
	3	RO Holding Register	R	0=OFF 1=Run Allowed Default: NA	Reflects the running mode of the chiller. Run Enabled indicates that the chiller can start if operating conditions are met.
<b>Units</b>					
	316	RW Holding Register	R	0=English 1=Metric Default: English	Sets the type of units (English or Metric) sent from the chiller unit controller to the Modbus network.

**Table 12: Circuit and Compressor Data Points**

Chiller Data Point	Holding Register	Data Type	Read/Write Access	Range/Default (In Units)	Description
<b>Compressor Current</b>					
Circuit 1 Compressor 1	70	RO Holding Register	R	0 – 10,000 Amps Default: NA	Indicates the average current of the compressor motor.
Circuit 1 Compressor 2	83				
<b>Compressor Percent RLA</b>					
Circuit 1 Compressor 1	69	RO Holding Register	R	0 – 100% Default: NA	Indicates the current percent RLA for the compressor motor.
Circuit 1 Compressor 2	82				
<b>Compressor Power</b>					
Circuit 1 Compressor 1	72	RO Holding Register	R	0 – 3,500 kW Default: NA	Indicates the current power of the compressor motor.
Circuit 1 Compressor 2	85				
<b>Compressor Run Hours</b>					
Circuit 1 Compressor 1	74-75	RO Holding Register	R	0 – 999,999 hours Default: NA	Indicates the number of hours that the compressor motor has been turned on.
Circuit 1 Compressor 2	87-88				
Circuit 1 Compressor 3	100-101				
Circuit 2 Compressor 1	113-114				
Circuit 2 Compressor 2	126-127				
Circuit 2 Compressor 3	139-140				
<b>Compressor Starts</b>					
Circuit 1 Compressor 1	73	RO Holding Register	R	0 – 65,535 starts Default: NA	Indicates the number of times the compressor motor has been started.
Circuit 1 Compressor 2	86				
Circuit 1 Compressor 3	99				
Circuit 2 Compressor 1	112				
Circuit 2 Compressor 2	125				
Circuit 2 Compressor 3	138				
<b>Compressor Voltage</b>					
Circuit 1 Compressor 1	71	RO Holding Register	R	0 – 15,000 VAC Default: NA	Indicates the average voltage of the compressor motor.
Circuit 1 Compressor 2	84				
<b>Condenser Refrigerant Pressure</b>					
Circuit 1	39	RO Holding Register	R	-14.5 to 43.51 Psi × 10 (R1233zd(E)) -100 to 300 kPa × 10 (R1233zd(E)) 0-700 Psi × 10 (R32) 0-2827 kPa × 10 (R32) Default: NA	Indicates the current condenser pressure.
Circuit 2	43				
<b>Condenser Saturated Refrigerant Temperature</b>					
Circuit 1	40	RO Holding Register	R	-14.98 – 185°F × 10 -26.1 – 85°C × 10 Default: NA	Indicates the current saturated refrigerant temperature of the condenser.
Circuit 2	44				
<b>Discharge Refrigerant Pressure</b>					
Circuit 1 Compressor 1	66	RO Holding Register	R	-14.5 to 43.51 Psi × 10 (R1233zd(E)) -100 to 300 kPa × 10 (R1233zd(E)) Default: NA	The current discharge refrigerant pressure for the compressor.
Circuit 1 Compressor 2	79				

Discharge Refrigerant Temperature					
Circuit 1 Compressor 1	68	RO Holding Register	R	-40 - 249.8°F × 10 -40 - 121°C × 10 Default: NA	Indicates the current discharge refrigerant temperature for the circuit or compressor.  NOTE: On AGZ-F, there is a single sensor per circuit.
Circuit 1 Compressor 2	81				
Circuit 2 Compressor 1	107				
Discharge Saturated Refrigerant Temperature					
Circuit 1 Compressor 1	67	RO Holding Register	R	-40 - 230°F × 10 -40 - 110°C × 10 Default: NA	The current discharge saturated refrigerant temperature for the compressor.
Circuit 1 Compressor 2	80				
Evaporator Refrigerant Pressure					
Circuit 1	41	RO Holding Register	R	-14.5 to 21.76 Psi × 10 (R1233zd(E)) -100 to 150 kPa × 10 (R1233zd(E)) 0-350 Psi × 10 (R32) 0-2413 kPa × 10 (R32) Default: NA	Indicates the current evaporator pressure.
Circuit 2	45				
Evaporator Saturated Refrigerant Temperature					
Circuit 1	42	RO Holding Register	R	-40 - 230°F × 10 -40 - 110°C × 10 Default: NA	Indicates the current saturated refrigerant temperature of the evaporator.
Circuit 2	46				
Liquid Line Refrigerant Temperature					
Circuit 1	1984	RO Holding Register	R	-40 - 230°F × 10 -40 - 110°C × 10 Default: NA	Indicates the liquid line refrigerant temperature for the circuit.
Suction Refrigerant Pressure					
Circuit 1 Compressor 1	63	RO Holding Register	R	-14.5 to 21.76 Psi × 10 (R1233zd(E)) -100 to 150 kPa × 10 (R1233zd(E)) Default: NA	The current suction refrigerant pressure for the compressor.
Circuit 1 Compressor 2	76				
Suction Refrigerant Temperature					
Circuit 1 Compressor 1	65	RO Holding Register	R	-40 - 230°F × 10 -40 - 110°C × 10 Default: NA	Indicates the current suction refrigerant temperature for the circuit or compressor.  NOTE: On AGZ-F, there is a single sensor per circuit.
Circuit 1 Compressor 2	78				
Circuit 1	1990				
Circuit 2	1974				
Suction Saturated Refrigerant Temperature					
Circuit 1 Compressor 1	64	RO Holding Register	R	-40 - 230°F × 10 -40 - 110°C × 10 Default: NA	The current suction saturated refrigerant temperature for the compressor.
Circuit 1 Compressor 2	77				

**Table 13: Pump Data Points**

Chiller Data Point	Holding Register	Data Type	Read/Write Access	Range/Default (In Units)	Description
<b>Condenser Pump 1 Run Hours</b>					
Pump 1	297-298	RO Holding Register	R	0 – 999,999 Hrs Default: NA	Indicates the number of hours that the pump motor has been turned ON. There is separate Holding Register for each pump.
Pump 2	300-301				
<b>Condenser Pump 1 Status</b>					
Pump 1	299	RO Holding Register	R	0=Pump OFF Request 1=Pump ON Request Default: NA	Indicates if the pump has been commanded ON or OFF. There is a separate Holding Register for each pump.
Pump 2	302				
<b>Evaporator Pump 1 Run Hours</b>					
Pump 1	303-304	RO Holding Register	R	0 – 999,999 Hrs Default: NA	Indicates the number of hours that the pump motor has been turned ON. There is separate Holding Register for each pump.
Pump 2	306-307				
<b>Evaporator Pump 1 Status</b>					
Pump 1	305	RO Holding Register	R	0=Pump OFF Request 1=Pump ON Request Default: NA	Indicates if the pump has been commanded ON or OFF. There is a separate Holding Register for each pump.
Pump 2	308				

# Alarm Management

The Chiller Unit Controller has various ways of managing alarms, depending on the protocol. Using one of the mechanisms available, alarms can be recognized and acknowledged by alarm class and can be cleared from the network.

## Alarm Classes

Alarms in the unit controller are divided into three classes: Faults, Problems, and Warnings. Fault alarms have the highest priority. Problem alarms have the next priority. Warning alarms have the lowest priority. The alarms within each class are not prioritized in any way. Refer to the Chiller Controller Operation Manual ([www.DaikinApplied.com](http://www.DaikinApplied.com)) for a thorough explanation of each alarm.

## Fault Alarms

Fault alarms require an acknowledgement from the operator. These alarms indicate that the compressor or unit is shut down.

## Problem Alarms

Problem alarms do not cause the compressor or unit to shut down but do limit operation of the chiller in some way.

## Warning Alarms

A warning is announced whenever an abnormal condition exists which does not affect chiller operation.

## Alarm Monitoring

The Chiller Unit Controller offers several alarm data points, which provide specific information for each possible chiller alarm. Each of these data points exists for each class of alarm: Faults, Problems, and Warnings. These data points are described below.

## Alarm Index

The Alarm Index provides a unique index value for each alarm that can occur for the chiller. The index value identifies the basic information about the type of alarm that occurred. Monitoring only the Alarm Index is likely sufficient for many users. If additional information is desired, the Alarm Module Type, Alarm Module ID and Alarm Payload can also be monitored.

## Alarm Module Type

The Alarm Module Type indicates the specific alarm module type, unit, compressor, VFD, etc., in alarm.

## Alarm Module ID

The Alarm Module ID indicates the specific alarm module, compressor number, fan number, VFD number, etc., in alarm. Alarm Module ID does not apply for all alarms.

## Alarm Module Payload

The Alarm Module Payload is typically used for hardware manufacturer alarm code information, such as VFD, MB, or ECM fan alarms. Alarm Module Payload does not apply for all alarms.

**Table 14: Alarms by Chiller Model**

Alarm Description	AGZ-F	WMT	WMC-E
Bad demand limit input	X		
Bad setpoint override input	X		
Chiller Network Communication Failure	X		
COMPRESSOR LOCKOUT - Number of Allowed Re-Starts Exceeded	X		
COMPRESSOR SHUTDOWN - Compressor Fault			X
COMPRESSOR SHUTDOWN - Compressor VFD Fault		X	
COMPRESSOR SHUTDOWN - Condenser Pressure High		X	
COMPRESSOR SHUTDOWN - Condenser Pressure Sensor Fault	X	X	
COMPRESSOR SHUTDOWN - Condenser Water Flow Loss		X	X
COMPRESSOR SHUTDOWN - Current High with Compressor OFF			X
COMPRESSOR SHUTDOWN - Current Overload Trip (or Motor Current High)		X	X
COMPRESSOR SHUTDOWN - Discharge Pressure High		X	X
COMPRESSOR SHUTDOWN - Discharge Temperature High	X	X	X
COMPRESSOR SHUTDOWN - Discharge Temperature Sensor Fault	X		
COMPRESSOR SHUTDOWN - Evaporator Pressure Low		X	
COMPRESSOR SHUTDOWN - Evaporator Pressure Sensor Fault	X	X	
COMPRESSOR SHUTDOWN - High Condenser Pressure	X		
COMPRESSOR SHUTDOWN - IPS Over Temperature		X	
COMPRESSOR SHUTDOWN - Low Evaporator Pressure	X		
COMPRESSOR SHUTDOWN - Low Motor Current			X
COMPRESSOR SHUTDOWN - MBC Fault		X	
COMPRESSOR SHUTDOWN - Ground Fault Trip			X
COMPRESSOR SHUTDOWN - MBC Modbus Communication Fault		X	
COMPRESSOR SHUTDOWN - Mechanical High Pressure Trip	X		
COMPRESSOR SHUTDOWN - Mechanical Low Pressure Trip	X		
COMPRESSOR SHUTDOWN - Motor Protector Trip	X		
COMPRESSOR SHUTDOWN - Motor Temperature High			X
COMPRESSOR SHUTDOWN - No Pressure Change After Start	X		

Alarm Description	AGZ-F	WMT	WMC-E
COMPRESSOR SHUTDOWN - No Starter Transition			X
COMPRESSOR SHUTDOWN - Overvoltage			X
COMPRESSOR SHUTDOWN - Undervoltage			X
COMPRESSOR SHUTDOWN - Stator Temperature High		X	
COMPRESSOR SHUTDOWN - Starter Fault Compressor			X
COMPRESSOR SHUTDOWN - Suction Pressure Low		X	X
COMPRESSOR SHUTDOWN - Suction Temperature Sensor Fault	X		
COMPRESSOR SHUTDOWN - Surge Suction Superheat High-Running			X
COMPRESSOR SHUTDOWN - VFD Enable Circuit Fault		X	
COMPRESSOR SHUTDOWN - VFD Modbus Communication Fault		X	
COMPRESSOR START ABORT - Interlock Switch			X
Condenser Entering Water Temperature Sensor Failure		X	X
Condenser Leaving Water Temperature Sensor Failure (STOP If Heat)		X	X
CONDENSER PUMP ON - Condenser Water Freeze Protection		X	X
Controller board offline	X	X	X
DC Fan Fault	X		
Economizer Pressure Sensor Failure		X	
Economizer Pressure Sensor Warning		X	
Economizer Temperature Sensor Warning		X	
Evap EXV Module Communications Fault	X		
Evaporator Entering Water Temperature Sensor Failure	X	X	X
EVAPORATOR PUMP ON - Evaporator Water Freeze Protection		X	
Expansion Alarm – Fault		X	X
Expansion Alarm – Problem			X
Expansion Alarm – Warning		X	X
External Event	X		
Liquid Line Refrigerant Temperature Sensor Failure			X
Low Suction SH	X		
Low Condenser Sat. Temperature	X		
Phase Voltage Monitor/Ground Fault Protection Alarm	X		
Power Loss While Running		X	
PUMP #1 START ATTEMPTED - Evaporator Pump #2 Failure	X	X	
PUMP #1 START ATTEMPTED - Condenser Pump #2 Failure		X	
PUMP #2 START ATTEMPTED - Evaporator Pump #1 Failure	X	X	
PUMP #2 START ATTEMPTED - Condenser Pump #1 Failure		X	

Alarm Description	AGZ-F	WMT	WMC-E
START INHIBITED - Ambient Temperature Low	X		
Transformer Overtemperature Fault	X		
Transformer Temperature Sensor Error	X		
UNIT SHUTDOWN - Condenser Freeze Protect		X	
UNIT SHUTDOWN - Evaporator Leaving Water Temperature Sensor Fault	X	X	X
UNIT SHUTDOWN - Evaporator Freeze Protect	X	X	
UNIT SHUTDOWN - Evaporator Water Flow Loss	X	X	X
UNIT SHUTDOWN - Outside Air Temperature Sensor Fault	X		
UNIT STOP - External Alarm	X		X

## BACnet Alarms

### BACnet Alarm Monitoring

The Chiller Unit Controller may have alarms monitored by one of two methods: Alarm Digital Output or Alarm Class.

#### Monitor Alarm by BACnet Digital Output

To monitor whether there is any active alarm, read the Alarm Digital Output object. If the Present\_Value is Inactive (0), no alarms are active. If the Present\_Value is Active (1), there is at least one alarm active in the chiller.

#### Monitor by Alarm Class (Alarm Index, Alarm Module Type, Alarm Module ID, Alarm Module Payload)

To monitor alarms by alarm class, read the Present\_Value of the appropriate Analog Value objects (Warnings, Problems and Faults). The Present\_Value displays a value that corresponds to the highest alarm index that is active. It is possible to have multiple active alarms, but only the alarm with the highest index is displayed. If the Present\_Value displays a zero, there are no active alarms.

## Clearing Alarms

Alarms within the Chiller Unit Controller can be cleared via BACnet by setting the Clear Alarms object to a value of 1. After the alarms are cleared, this variable returns to Normal (0). Refer to [Table 8](#), Clear Alarm - Network. Many alarms are automatically clearing alarms. Refer to the respective chiller Installation, Operation and Maintenance Manual (IOM), available on [www.DaikinApplied.com](http://www.DaikinApplied.com), for details on auto-clearing alarms.

## BACnet Alarm Indices

This section provides a comprehensive description of all alarm codes supported by the MicroTech WME Chiller Unit Controllers. The following tables display details for each of the three alarm types: Warnings, Problems, and Faults.

**Table 15: BACnet Warning Alarm Indices**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:902	R	AVWarningAlarm	This object indicates the active warning alarm. The alarms are not ordered based on any priority. If multiple warning alarms are present at one time, this object will be set to the alarm that has the highest alarm index. This object is set to zero if no warning alarms are active.
Alarm Warning Index	Description		
0	No Alarms		
1	Condenser Entering Water Temperature Sensor Failure		
2	Evaporator Entering Water Temperature Sensor Failure		
3	Liquid Line Refrigerant Temperature Sensor Failure		
4	Condenser Leaving Water Temperature Sensor Failure (STOP if Heat)		
8	Bad setpoint override input		
9	Bad demand limit input		
10	Power Loss While Running		
13	External Event		
17	Chiller Network Communication Failure		
24	Economizer Pressure Sensor Warning		
25	Economizer Temperature Sensor Warning		
63	Expansion Alarm – Warning		

**Table 16: BACnet Problem Alarm Indices**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:900	R	AVProblemAlarm	This object indicates the active problem alarm. The alarms are not ordered based on any priority. If multiple problem alarms are present at one time, this object will be set to the alarm that has the highest alarm index. This object is set to zero if no problem alarms are active.
Problem Alarm Index	Description		
0	No Alarms		
33	DC Fan Fault		
65	START INHIBITED - Ambient Temperature Low		
70	CONDENSER PUMP ON - Condenser Water Freeze Protection		
71	PUMP #2 START ATTEMPTED - Condenser Pump #1 Failure		
72	PUMP #1 START ATTEMPTED - Condenser Pump #2 Failure		
81	PUMP #2 START ATTEMPTED - Evaporator Pump #1 Failure		
82	PUMP #1 START ATTEMPTED - Evaporator Pump #2 Failure		
126	Expansion Alarm – Problem		
246	Transformer Temp Sensor Error		

Table 17: BACnet Fault Alarm Indices

Object Type/ Instance	Read/ Write Access	BACnet Object Name	Description
AV:901	R	AVFaultA- alarm	This object indicates the active fault alarm. The alarms are not ordered based on any priority. If multiple fault alarms are present at one time, this object will be set to the alarm that has the highest alarm index. This object is set to zero if no fault alarms are active.
Fault Alarm Index	Description		
0	No Alarms		
18	Economizer Pressure Sensor Failure		
32	Evap EXV Module Communications Fault		
103	COMPRESSOR SHUTDOWN - Suction Pressure Low		
104	COMPRESSOR SHUTDOWN - Discharge Pressure High		
106	COMPRESSOR SHUTDOWN - Stator Temperature High		
112	COMPRESSOR SHUTDOWN - MBC Fault		
115	COMPRESSOR SHUTDOWN - VFD Enable Circuit Fault		
116	COMPRESSOR SHUTDOWN - MBC Modbus Communication Fault		
117	COMPRESSOR SHUTDOWN - VFD Modbus Communication Fault		
120	COMPRESSOR SHUTDOWN - IPS Over Temperature		
128	UNIT SHUTDOWN - Outside Air Temperature Sensor Fault		
129	COMPRESSOR SHUTDOWN - Current Overload Trip or Motor Current High		
131	COMPRESSOR SHUTDOWN – Low Motor Current		
133	COMPRESSOR SHUTDOWN - Motor Protector Trip		
135	COMPRESSOR SHUTDOWN - Motor Temperature High		
139	COMPRESSOR SHUTDOWN - Overvoltage		
140	COMPRESSOR SHUTDOWN - Undervoltage		
141 or 142	COMPRESSOR SHUTDOWN - Condenser Pressure Sensor Fault		
143	COMPRESSOR SHUTDOWN - Condenser Water Flow Loss		
144	COMPRESSOR SHUTDOWN - Condenser Pressure High		
145	COMPRESSOR SHUTDOWN - High Condenser Pressure		
146	COMPRESSOR SHUTDOWN - Current High with Compressor OFF		
147	COMPRESSOR SHUTDOWN - Discharge Temperature Sensor Fault		
148	COMPRESSOR SHUTDOWN - Discharge Temperature High		
150	UNIT SHUTDOWN - Evaporator Water Flow Loss		
151	UNIT SHUTDOWN - Evaporator Freeze Protect		
152	COMPRESSOR SHUTDOWN - Evaporator Pressure Low		

153	COMPRESSOR SHUTDOWN - Low Evaporator Pressure
154 or 155	COMPRESSOR SHUTDOWN - Evaporator Pressure Sensor Fault
161	COMPRESSOR LOCKOUT - Number of Allowed Re-Starts Exceeded
162	UNIT SHUTDOWN - Evaporator Leaving Water Temperature Sensor Fault
166	COMPRESSOR SHUTDOWN - Mechanical High Pressure Trip
177	COMPRESSOR SHUTDOWN - Starter Fault Compressor
178	COMPRESSOR SHUTDOWN - No Starter Transition
181	COMPRESSOR SHUTDOWN - Surge Suction Superheat High-Running
183	COMPRESSOR SHUTDOWN - Suction Temperature Sensor Fault
184	COMPRESSOR START ABORT - Vanes Open OR No Start – Interlock Switch
185	COMPRESSOR SHUTDOWN – Compressor Fault
186	COMPRESSOR SHUTDOWN - Mechanical Low Pressure Trip
188	Controller board offline
189	COMPRESSOR SHUTDOWN - No Pressure Change After Start
194	UNIT STOP - External Alarm
199	COMPRESSOR SHUTDOWN - Compressor VFD Fault
219	Low Suction SH
220	Low Condenser Sat. Temperature
223	Expansion Alarm – Fault
228	Phase Voltage Monitor/Ground Fault Protection Alarm
233	UNIT SHUTDOWN - Condenser Freeze Protect
247	Transformer Overtemperature Fault

## BACnet Alarm Module Types

This section provides a comprehensive description of all BACnet alarm module types supported by the Chiller Unit Controller.

Tables 18–“Table 20: BACnet Fault Alarm Module Types” on page 29 display details for each of the three alarm types: Warnings, Problems, and Faults.

**Table 18: BACnet Warning Alarm Module Types**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:912	R	AVWarningMod-Type	This object indicates the specific Alarm Module Type (unit, compressor, VFD, etc.) for the active Warning Alarm Index. This object is set to zero if no warning alarms are active.
Module Type Value	Description		
0	No Alarms		
1	Unit		
2	Compressor		
3	Fans		
4	cpCOe Expansion Module		
5	Sensor		
6	EXV		
7	BAS Expansion Module		
8	Circuit		
9	Peripherals Modbus		
10	VFD		
11	MBC		
12	IGV		
13	Pump		
14	Purge Unit		
15	Harmonic Filter		
100	PC		

**Table 19: BACnet Problem Alarm Module Types**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:906	R	AVProblemMod-Type	This object indicates the specific Alarm Module Type (unit, compressor, VFD, etc.) for the active Problem Alarm Index. This object is set to zero if no problem alarms are active.
Module Type Value	Description		
0	No Alarms		
1	Unit		
2	Compressor		
3	Fans		
4	cpCOe Expansion Module		
5	Sensor		
6	EXV		
7	BAS Expansion Module		

8	Circuit
9	Peripherals Modbus
10	VFD
11	MBC
12	IGV
13	Pump
14	Purge Unit
15	Harmonic Filter
100	PC

**Table 20: BACnet Fault Alarm Module Types**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:909	R	AVFault-ModType	This object indicates the specific Alarm Module Type (unit, compressor, VFD, etc.) for the active Fault Alarm Index. This object is set to zero if no fault alarms are active.
Module Type Value	Description		
0	No Alarms		
1	Unit		
2	Compressor		
3	Fans		
4	cpCOe Expansion Module		
5	Sensor		
6	EXV		
7	BAS Expansion Module		
8	Circuit		
9	Peripherals Modbus		
10	VFD		
11	MBC		
12	IGV		
13	Pump		
14	Purge Unit		
15	Harmonic Filter		
100	PC		

## BACnet Alarm Module ID

This object indicates the specific Alarm Module ID (unit, compressor, VFD, etc.) for the active Fault Alarm Index. This object is set to zero if no fault alarms are active. The following tables display details for each of the three alarm classes: Warning, Problem, and Fault.

**Table 21: BACnet Warning Alarm Module ID**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:913	R	AVWarningModID	This object indicates the specific Alarm Module ID (compressor number, fan number, VFD number, etc.) for the Alarm Module Type currently in alarm. This object is set to zero if no warning alarms are active or if Alarm Module ID does not apply for the Alarm Module Type in alarm (Unit-level alarms, for example).
Module ID Value	Description		
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type		
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm		

**Table 22: BACnet Problem Alarm Module ID**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:907	R	AVProblemModID	This object indicates the specific Alarm Module ID (compressor number, fan number, VFD number, etc.) for the Alarm Module Type currently in alarm. This object is set to zero if no problem alarms are active or if Alarm Module ID does not apply for the Alarm Module Type in alarm (Unit-level alarms, for example).
Module ID Value	Description		
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type		
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm		

**Table 23: BACnet Fault Alarm Module ID**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:910	R	AVFaultModID	This object indicates the specific Alarm Module ID (compressor number, fan number, VFD number, etc.) for the Alarm Module Type currently in alarm. This object is set to zero if no fault alarms are active or if Alarm Module ID does not apply for the Alarm Module Type in alarm (Unit-level alarms, for example).
Module ID Value	Description		
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type		
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm		

## BACnet Alarm Module Payload

This section provides a comprehensive description of all BACnet alarm module payloads supported by the Chiller Unit Controller. The following tables display details for each of the three alarm classes: Warning, Problem, and Fault. Refer to the appropriate unit IOM for more details.

**Table 24: BACnet Warning Alarm Module Payload**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:914	R	AVWarningMod-Payload	This object indicates the specific Alarm Module Payload for the active warning alarm index. The Alarm Module Payload is typically used for hardware manufacturer alarm code information, such as VFD, MBC or ECM fan alarms. Please refer to the unit Installation, Operation and Maintenance Manual (IOM) for a list of model-specific payload values. This object is set to zero if no warning alarms are active or if Alarm Module Payload does not apply for the Alarm Module Type and Alarm Module ID in alarm (Unit-level alarms, for example).
Module Payload Value	Description		
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type		
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm		

**Table 25: BACnet Problem Alarm Module Payload**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:908	R	AVProblem-ModPayload	This object indicates the specific Alarm Module Payload for the active problem alarm index. The Alarm Module Payload is typically used for hardware manufacturer alarm code information, such as VFD, MBC or ECM fan alarms. Please refer to the unit Installation, Operation and Maintenance Manual (IOM) for a list of model-specific payload values. This object is set to zero if no problem alarms are active or if Alarm Module Payload does not apply for the Alarm Module Type and Alarm Module ID in alarm (Unit-level alarms, for example).
Module Payload Value	Description		
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type		
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm		

**Table 26: BACnet Fault Alarm Module Payload**

Object Type/Instance	Read/Write Access	BACnet Object Name	Description
AV:911	R	AVFault-ModPayload	This object indicates the specific Alarm Module Payload for the active fault alarm index. The Alarm Module Payload is typically used for hardware manufacturer alarm code information, such as VFD, MBC or ECM fan alarms. Please refer to the unit Installation, Operation and Maintenance Manual (IOM) for a list of model-specific payload values. This object is set to zero if no fault alarms are active or if Alarm Module Payload does not apply for the Alarm Module Type and Alarm Module ID in alarm (Unit-level alarms, for example).
Module Payload Value	Description		
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type		
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm		

## Modbus Alarms

### Modbus Alarm Monitoring

The Chiller Unit Controller may have alarms monitored by one of two methods: Alarm Digital Output or Alarm Class.

#### **Monitor Alarm by Alarm Digital Output**

To monitor whether there is any active alarm, read the Alarm Digital Output Holding Register. If the value is Inactive (0), no alarms are active. If the value is Active (1), there is at least one alarm active in the chiller.

#### **Monitor by Alarm Class (Alarm Index, Alarm Module Type, Alarm Module ID, Alarm Module Payload)**

To monitor alarms by alarm class, read the value of the appropriate Holding Registers for (Warnings, Problems and Faults). The Holding Registers display a value that corresponds to the highest alarm index that is active. It is possible to have multiple active alarms, but only the alarm with the highest index is displayed. If the Holding Register displays a zero, there are no active alarms.

### Clearing Alarms

Alarms within the Chiller Unit Controller can be cleared via Modbus by setting the Clear Alarms Holding Register to a value of 1. After the alarms are cleared, this variable returns to Normal (0). Refer to Table 11, Clear Alarm - Network. Many alarms are automatically clearing alarms. Refer to the respective chiller Installation, Operation and Maintenance Manual (IOM), available on [www.DaikinApplied.com](http://www.DaikinApplied.com), for details on auto-clearing alarms.

## Modbus Alarm Indices

This section provides a comprehensive description of all alarm indices supported by the Chiller Unit Controllers. Tables 27–29 display details for each of the three alarm types: Warnings, Problems, and Faults.

**Table 27: Modbus Warning Alarm Indices**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Warning Alarm Index	28	RO Holding Register	R	This register indicates the active warning alarm. The alarms are not ordered based on any priority. If multiple warning alarms are present at one time, this object will be set to the alarm that has the highest alarm index. This object is set to zero if no warning alarms are active.
Alarm Code	Description			
0	No Alarms			
1	Condenser Entering Water Temperature Sensor Failure			
2	Evaporator Entering Water Temperature Sensor Failure			
3	Liquid Line Refrigerant Temperature Sensor Failure			
4	Condenser Leaving Water Temperature Sensor Failure (STOP if Heat)			
8	Bad setpoint override input			
9	Bad demand limit input			
10	Power Loss While Running			
13	External Event			
17	Chiller Network Communication Failure			
24	Economizer Pressure Sensor Warning			
25	Economizer Temperature Sensor Warning			
63	Expansion Alarm – Warning			

**Table 28: Modbus Problem Alarm Indices**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Problem Alarm Index	29	RO Holding Register	R	This register indicates the active problem alarm. The alarms are not ordered based on any priority. If multiple problem alarms are present at one time, this object will be set to the alarm that has the highest alarm index. This object is set to zero if no problem alarms are active.
Alarm Code	Description			
0	No Alarms			
33	DC Fan Fault			
65	START INHIBITED - Ambient Temperature Low			
70	CONDENSER PUMP ON - Condenser Water Freeze Protection			
71	PUMP #2 START ATTEMPTED - Condenser Pump #1 Failure			
72	PUMP #1 START ATTEMPTED - Condenser Pump #2 Failure			
81	PUMP #2 START ATTEMPTED - Evaporator Pump #1 Failure			
82	PUMP #1 START ATTEMPTED - Evaporator Pump #2 Failure			
126	Expansion Alarm – Problem			
246	Transformer Temp Sensor Error			

**Table 29: Modbus Fault Alarm Indices**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Fault Alarm Index	30	RO Holding Register	R	This register indicates the active fault alarm. The alarms are not ordered based on any priority. If multiple fault alarms are present at one time, this object will be set to the alarm that has the highest alarm index. This object is set to zero if no fault alarms are active.
Alarm Code	Description			
0	No Alarms			
18	Economizer Pressure Sensor Failure			
32	Evap EXV Module Communications Fault			
103	COMPRESSOR SHUTDOWN - Suction Pressure Low			
104	COMPRESSOR SHUTDOWN - Discharge Pressure High			
106	COMPRESSOR SHUTDOWN - Stator Temperature High			
112	COMPRESSOR SHUTDOWN - MBC Fault			
115	COMPRESSOR SHUTDOWN - VFD Enable Circuit Fault			
116	COMPRESSOR SHUTDOWN - MBC Modbus Communication Fault			
117	COMPRESSOR SHUTDOWN - VFD Modbus Communication Fault			
120	COMPRESSOR SHUTDOWN - IPS Over Temperature			
128	UNIT SHUTDOWN - Outside Air Temperature Sensor Fault			
129	COMPRESSOR SHUTDOWN - Current Overload Trip or Motor Current High			
131	COMPRESSOR SHUTDOWN – Low Motor Current			
133	COMPRESSOR SHUTDOWN - Motor Protector Trip			
135	COMPRESSOR SHUTDOWN - Motor Temperature High			
139	COMPRESSOR SHUTDOWN - Overvoltage			
140	COMPRESSOR SHUTDOWN - Undervoltage			
141 or 142	COMPRESSOR SHUTDOWN - Condenser Pressure Sensor Fault			
143	COMPRESSOR SHUTDOWN - Condenser Water Flow Loss			

144	COMPRESSOR SHUTDOWN - Condenser Pressure High
145	COMPRESSOR SHUTDOWN - High Condenser Pressure
146	COMPRESSOR OFF - Current High with Compressor OFF
147	COMPRESSOR SHUTDOWN - Discharge Temperature Sensor Fault
148	COMPRESSOR SHUTDOWN - Discharge Temperature High
150	UNIT SHUTDOWN - Evaporator Water Flow Loss
151	UNIT SHUTDOWN - Evaporator Freeze Protect
152	COMPRESSOR SHUTDOWN - Evaporator Pressure Low
153	COMPRESSOR SHUTDOWN - Low Evaporator Pressure
154 or 155	COMPRESSOR SHUTDOWN - Evaporator Pressure Sensor Fault
161	COMPRESSOR LOCKOUT - Number of Allowed Re-Starts Exceeded
162	UNIT SHUTDOWN - Evaporator Leaving Water Temperature Sensor Fault
166	COMPRESSOR SHUTDOWN - Mechanical High Pressure Trip
177	COMPRESSOR SHUTDOWN - Starter Fault Compressor
178	COMPRESSOR SHUTDOWN - No Starter Transition
181	COMPRESSOR SHUTDOWN - Surge Suction Superheat High-Running
183	COMPRESSOR SHUTDOWN - Suction Temperature Sensor Fault
184	COMPRESSOR START ABORT - Vanes Open OR No Start – Interlock Switch
185	COMPRESSOR SHUTDOWN – Compressor Fault
186	COMPRESSOR SHUTDOWN - Mechanical Low Pressure Trip
188	Controller board offline
189	COMPRESSOR SHUTDOWN - No Pressure Change After Start
194	UNIT STOP - External Alarm
199	COMPRESSOR SHUTDOWN - Compressor VFD Fault
219	Low Suction SH
220	Low Condenser Sat. Temperature
223	Expansion Alarm – Fault
228	Phase Voltage Monitor/Ground Fault Protection Alarm
233	UNIT SHUTDOWN - Condenser Freeze Protect
247	Transformer Overtemperature Fault

## Modbus Alarm Module Types

This section provides a comprehensive description of all Modbus alarm module types supported by the Chiller Unit Controller. The following tables display details for each of the three alarm classes: Warning, Problem, and Fault.

**Table 30: Modbus Warning Alarm Module Type**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Warning Alarm Module Type	2001	RO Holding Register	R	This register indicates the specific Alarm Module Type (unit, compressor, VFD, etc.) for the active Warning Alarm Index. This object is set to zero if no warning alarms are active.
Alarm Code	Description			
0	No Alarms			
1	Unit			
2	Compressor			
3	Fan			
4	cpCOe Expansion Module			
5	Sensor			
6	EXV			
7	BAS Expansion Module			
8	Circuit			
9	Peripherals Modbus			
10	VFD			
11	MBC			
12	IGV			
13	Pump			
14	Purge Unit			
15	Harmonic Filter			
100	PC			

**Table 31: Modbus Problem Alarm Module Type**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Problem Alarm Module Type	2004	RO Holding Register	R	This register indicates the specific Alarm Module Type (unit, compressor, VFD, etc.) for the active Problem Alarm Index. This object is set to zero if no warning alarms are active.
Alarm Code	Description			
0	No Alarms			
1	Unit			
2	Compressor			
3	Fan			
4	cpCOe Expansion Module			
5	Sensor			
6	EXV			
7	BAS Expansion Module			
8	Circuit			
9	Peripherals Modbus			
10	VFD			
11	MBC			
12	IGV			
13	Pump			
14	Purge Unit			
15	Harmonic Filter			
100	PC			

**Table 32: Modbus Fault Alarm Module Type**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Fault Alarm Module Type	2007	RO Holding Register	R	This register indicates the specific Alarm Module Type (unit, compressor, VFD, etc.) for the active Fault Alarm Index. This object is set to zero if no warning alarms are active.
Alarm Code	Description			
0	No Alarms			
1	Unit			
2	Compressor			
3	Fan			
4	cpCOe Expansion Module			
5	Sensor			
6	EXV			
7	BAS Expansion Module			
8	Circuit			
9	Peripherals Modbus			
10	VFD			
11	MBC			
12	IGV			
13	Pump			
14	Purge Unit			
15	Harmonic Filter			
100	PC			

## Modbus Alarm Module ID

This section provides a comprehensive description of all Modbus alarm module ID's supported by the Chiller Unit Controller.

**Table 33: Modbus Warning Alarm Module ID**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Warning Alarm Module ID	2002	RO Holding Register	R	This register indicates the specific Alarm Module ID (compressor number, fan number, VFD number, etc.) for the Alarm Module Type currently in alarm. This object is set to zero if no warning alarms are active or if Alarm Module ID does not apply for the Alarm Module Type in alarm (Unit-level alarms, for example).
Alarm Code	Description			
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type			
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm			

**Table 34: Modbus Problem Alarm Module ID**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Problem Alarm Module ID	2005	RO Holding Register	R	This register indicates the specific Alarm Module ID (compressor number, fan number, VFD number, etc.) for the Alarm Module Type currently in alarm. This object is set to zero if no problem alarms are active or if Alarm Module ID does not apply for the Alarm Module Type in alarm (Unit-level alarms, for example).
Alarm Code	Description			
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type			
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm			

**Table 35: Modbus Fault Alarm Module ID**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Fault Alarm Module ID	2008	RO Holding Register	R	This object indicates the specific Alarm Module ID (compressor number, fan number, VFD number, etc.) for the Alarm Module Type currently in alarm. This object is set to zero if no fault alarms are active or if Alarm Module ID does not apply for the Alarm Module Type in alarm (Unit-level alarms, for example).
Alarm Code	Description			
0	No Alarms or Alarm Module ID does not apply for the Alarm Module Type			
Any Non-Zero Value	The Alarm Module ID for the Alarm Module Type currently in alarm			

## Modbus Alarm Module Payload

This section provides a comprehensive description of all Modbus alarm module payloads supported by the Chiller Unit Controller. The following tables display details for each of the three alarm classes: Warning, Problem, and Fault.

**Table 36: Modbus Warning Alarm Module Payload**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Warning Alarm Module Payload	2003	RO Holding Register	R	This register indicates the specific Alarm Module Payload for the active warning alarm index. The Alarm Module Payload is typically used for hardware manufacturer alarm code information, such as VFD, MBC or ECM fan alarms. Please refer to the unit Installation, Operation and Maintenance Manual (IOM) for a list of model-specific payload values. This object is set to zero if no warning alarms are active or if Alarm Module Payload does not apply for the Alarm Module Type and Alarm Module ID in alarm (Unit-level alarms, for example).
<b>Alarm Code</b>	<b>Description</b>			
0	No Alarms or Alarm Module Payload does not apply for the Alarm Module Type in alarm			
Any Non-Zero Value	The Alarm Module Payload for the Alarm Module Type and Alarm Module ID currently in alarm			

**Table 37: Modbus Problem Alarm Module Payload**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Problem Alarm Module Payload	2006	RO Holding Register	R	This register indicates the specific Alarm Module Payload for the active problem alarm index. The Alarm Module Payload is typically used for hardware manufacturer alarm code information, such as VFD, MBC or ECM fan alarms. Please refer to the unit Installation, Operation and Maintenance Manual (IOM) for a list of model-specific payload values. This object is set to zero if no problem alarms are active or if Alarm Module Payload does not apply for the Alarm Module Type and Alarm Module ID in alarm (Unit-level alarms, for example).
<b>Alarm Code</b>	<b>Description</b>			
0	No Alarms or Alarm Module Payload does not apply for the Alarm Module Type in alarm			
Any Non-Zero Value	The Alarm Module Payload for the Alarm Module Type and Alarm Module ID currently in alarm			

**Table 38: Modbus Fault Alarm Module Payload**

Alarm	Holding Register	Data Type	Read/Write Access	Description
Fault Alarm Module Payload	2009	RO Holding Register	R	This register indicates the specific Alarm Module Payload for the active fault alarm index. The Alarm Module Payload is typically used for hardware manufacturer alarm code information, such as VFD, MBC or ECM fan alarms. Please refer to the unit Installation, Operation and Maintenance Manual (IOM) for a list of model-specific payload values. This object is set to zero if no fault alarms are active or if Alarm Module Payload does not apply for the Alarm Module Type and Alarm Module ID in alarm (Unit-level alarms, for example).
<b>Alarm Code</b>	<b>Description</b>			
0	No Alarms or Alarm Module Payload does not apply for the Alarm Module Type in alarm			
Any Non-Zero Value	The Alarm Module Payload for the Alarm Module Type and Alarm Module ID currently in alarm			

# Appendix A: PICS Statement

## BACnet Protocol Implementation Conformance Statement

**Date:** March 21, 2021

**Vendor Name:** Carel Industries S.p.A.

**Product Name:** c.pCO Family

**Product Model Number:** P+DDK0FH1DLF0

**BACnet Application Software Version:** 1.00.105

**BACnet Firmware Revision:** v4.8.001

**BACnet Protocol Revision:** 14

### Product Description:

The c.pCO is a native BACnet controller device with BACnet/IP and MS/TP capabilities.

### BACnet Standardized Device Profile (Annex L):

- BACnet Operator Workstation (B-OWS)
- BACnet Advanced Operator Workstation (B-AWS)
- BACnet Operator Display (B-OD)
- BACnet Building Controller (B-BC)
- BACnet Advanced Application Controller (B-AAC)
- BACnet Application Specific Controller (B-ASC)
- BACnet Smart Sensor (B-SS)
- BACnet Smart Actuator (B-SA)

### List all BACnet Interoperability Building Blocks Supported (Annex K):

DS-RP-B	DM-BR-B
DS-WP-A	DM-DDB-A
DS-WP-B	DM-DDB-B
DS-RPM-B	DM-DOB-B
DS-WPM-B	DM-DCC-B
AE-N-I-B	DM-TS-B
AE-ACK-B	DM-UTC-B
AE-INFO-B	DM-RD-B
AE-ESUM-B	DM-BR-B
SCHED-E-B	AE-ASUM-B
SCHED-I-B	DS-COV-B
T-VMT-I-B	DS-COVP-B
T-ATR-B	DS-COVU-B

### Segmentation Capability:

- Able to transmit segmented messages Window Size: 16
- Able to receive segmented messages Window Size: 16

**Table 39: Standard Object Types Supported**

**NOTE:** Modifying Writable Properties, such as State Text, Inactive Text, and Polarity, can lead to confusion when modified from defaults. When contacting technical support, all changes to default values should be disclosed.

Object Type	Optional Properties	Proprietary Properties	Writable Properties
Device	Active_COV_Subscriptions APDU_Segment_Timeout Backup_And_Restore_State Backup_Failure_Timeout Backup_Preparation_Time Configuration_Files Daylight_Savings_Status Description Last_Restore_Time Last_Restart_Reason Location Local_Date Local_Time Max_Master Max_Info_Frames Max_Segments_Accepted Restart_Notification_Recipients Restore_Completion_Time Restore_Preparation_Time Serial Number Time_of_Device_Restart UTC_Offset	(* See descriptions below) 77000 77001 77002 77003 77004 77005 77006 77007 77008 77017 77018 77019 77020	APDU_Timeout APDU_Segment_Timeout Backup_Failure_Timeout Description (max 255 chars) Location (max 64 chars) Max_Master Max_Info_Frames Number_Of_APDU_Retries Object_Name (max 64 chars) Restart_Notification_Recipients Restore_Completion_Time (* For Proprietary Properties See descriptions below) Proprietary Property 77004 Proprietary Property 77005 Proprietary Property 77008 Proprietary Property 77017 Proprietary Property 77018 Proprietary Property 77019 Proprietary Property 77020
Analog Input	Acked_Transitions COV_Increment Deadband Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Event_Time_Stamps High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Notify_Type Reliability Reliability_Evaluation_Inhibit Resolution Time_Delay Time_Delay_Normal	(** See descriptions below) 77009	Deadband Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Out_Of_Service Present_Value3 Reliability3 Reliability_Evaluation_Inhibit Resolution Time_Delay Time_Delay_Normal  3 Writable if Out_Of_Service is true
Analog Output	Acked_Transitions COV_Increment Deadband Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Event_Time_Stamps High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Notify_Type Reliability Reliability_Evaluation_Inhibit Resolution Time_Delay Time_Delay_Normal	(** See descriptions below) 77009	Deadband Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Out_Of_Service Present_Value Reliability3 Reliability_Evaluation_Inhibit Relinquish_Default Resolution Time_Delay Time_Delay_Normal  3 Writable if Out_Of_Service is true

Object Type	Optional Properties	Proprietary Properties	Writable Properties
<b>Analog Value</b>	Acked_Transitions COV_Increment Deadband Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Event_Time_Stamps High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Notify_Type Priority_Array1 Reliability Reliability_Evaluation_Inhibit Relinquish_Default1 Resolution Time_Delay Time_Delay_Normal  1 These Properties are present only if Proprietary Property 77009 = 2 or 130	(** See descriptions below) 77009	Deadband Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Out_Of_Service Present_Value2,3 Reliability3 Reliability_Evaluation_Inhibit Relinquish_Default Resolution Time_Delay Time_Delay_Normal + 2 Writable only if Proprietary Property 77009 = 1 or 2 or 129 or 130  3 Writable if Out_Of_Service is true
<b>Binary Input</b>	Acked_Transitions Active_Text Alarm_Value Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Event_Time_Stamps Inactive_Text Notification_Class Notify_Type Reliability Reliability_Evaluation_Inhibit Time_Delay Time_Delay_Normal	(** See descriptions below) 77009	Active_Text (max 32 chars) Alarm_Value Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Inactive_Text (max 32 chars) Notification_Class Out_Of_Service Polarity Present_Value3 Reliability3 Reliability_Evaluation_Inhibit Time_Delay Time_Delay_Normal  3 Writable if Out_Of_Service is true
<b>Binary Output</b>	Active_Text Description Inactive_Text Reliability	(** See descriptions below) 77009	Active_Text (max 32 chars) Inactive_Text (max 32 chars) Out_Of_Service Present_Value Polarity Reliability3 Relinquish_Default  3 Writable if Out_Of_Service is true

Object Type	Optional Properties	Proprietary Properties	Writable Properties
<b>Binary Value</b>	Acked_Transitions Active_Text Alarm_Value Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Event_Time_Stamps Notification_Class Notify_Type Inactive_Text Priority_Array1 Reliability Relinquish_Default1 Reliability_Evaluation_Inhibit Time_Delay Time_Delay_Normal  1 These Properties are present only if Proprietary Property 77009 = 2 or 130	(** See descriptions below) 77009	Active_Text (max 32 chars) Alarm_Value Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Inactive_Text (max 32 chars) Notification_Class Notify_Type Present_Value2,3 Reliability3 Reliability_Evaluation_Inhibit Relinquish_Default Time_Delay Time_Delay_Normal  2 Writable only if Proprietary Property 77009=1 or 2 or 129 or 130  3 Writable if Out_Of_Service is true
<b>Calendar</b>	Description	None	Description (max 255 chars) Object_Name (max 64 chars) Date_List (max 16)
<b>File</b>	Description	None	Archive
<b>Integer Value</b>	Acked_Transitions COV_Increment Deadband Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_State Event_Message_Texts Event_Time_Stamps High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Notify_Type Out_Of_Service Priority_Array 1 Reliability Relinquish_Default 1 Reliability_Evaluation_Inhibit Resolution Time_Delay Time_Delay_Normal  1 These Properties are present only if Proprietary Property 77009=2 or 130	(** See descriptions below) 77009	Deadband Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts (64 chars each) High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Out_Of_Service Present_Value2,3 Reliability3 Relinquish_Default Reliability_Evaluation_Inhibit Resolution Time_Delay Time_Delay_Normal  2 Writable only if Proprietary Property 77009=1 or 2 or 129 or 130  3 Writable if Out_Of_Service is true

Object Type	Optional Properties	Proprietary Properties	Writable Properties
<b>Multistate Input</b>	Acked_Transitions Alarm_Values Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts Event_Time_Stamps Fault_Values Notification_Class Notify_Type Reliability State_Text Reliability_Evaluation_Inhibit Time_Delay Time_Delay_Normal	(** See descriptions below) 77009	Alarm_Values Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts (64 chars each) Fault_Values Notification_Class Number_of_States (1 to 32) Out_Of_Service State_Text (max 32 chars per state) Present_Value3 Reliability3 Reliability_Evaluation_Inhibit Time_Delay Time_Delay_Normal  3 Writable if Out_Of_Service is true
<b>Multistate Output</b>	Description Reliability	(** See descriptions below) 77009	Number_of_States (1 to 32) Out_Of_Service State_Text State_Text (max 32 chars per state) Present_Value Reliability3 Relinquish_Default  3 Writable if Out_Of_Service is true
<b>Multistate Value</b>	Acked_Transitions Alarm_Values Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Event_Time_Stamps Fault_Values Notification_Class Notify_Type Priority_Array 1 Reliability Reliability_Evaluation_Inhibit Relinquish_Default1 State_Text Time_Delay Time_Delay_Normal  1 These Properties are present only if Proprietary Property 77009=2 or 130	(** See descriptions below) 77009	Alarm_Values Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Fault_Values Notification_Class Number_of_States (1 to 32) Out_Of_Service State_Text (max 32 chars per state) Present_Value2,3 Reliability3 Reliability_Evaluation_Inhibit Relinquish_Default Time_Delay Time_Delay_Normal  2 Writable only if Proprietary Property 77009=1 or 2 or 129 or 130 3 Writable if Out_Of_Service is true
<b>Notification Class</b>	Description	None	Ack_Required Description (max 255 chars) Object_Name (max 64 chars) Priority Recipient_List (max 4 entries)

Object Type	Optional Properties	Proprietary Properties	Writable Properties
<p><b>Positive Integer Value</b></p>	<p>Acked_Transitions COV_Increment Deadband Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_State Event_Message_Texts Event_Time_Stamps High_Limit Limit_Enable Low_Limit Max_Pres_Value Min_Pres_Value Notification_Class Out_Of_Service Max_Pres_Value Min_Pres_Value Notification_Class Notify_Type Out_Of_Service Priority_Array1 Reliability Relinquish_Default1 Reliability_Evaluation_Inhibit Resolution Time_Delay Time_Delay_Normal</p> <p>1 These Properties are present only if Proprietary Property 77009=2 or 130</p>	<p>(** See descriptions below) 77009</p>	<p>Deadband Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts (64 chars each) High_Limit Limit_Enable Low_Limit Present_Value2,3 Reliability3 Reliability_Evaluation_Inhibit Relinquish_Default Resolution Time_Delay Time_Delay_Normal</p> <p>2 Writable only if Proprietary Property 77009=1 or 2 or 129 or 130 3 Writable if Out_Of_Service is true</p>
<p><b>Schedule</b></p>	<p>Description Exception_Schedule Weekly_Schedule</p>	<p>None</p>	<p>Description (max 255 chars) Object_Name (max 64 chars) Out_of_Service Effective_Period Exception_Schedule (max 4 entries) List_Of_Object_Property_References (max 64 entries) Present_Value3 Priority_For_Writing Schedule_Default5 Weekly_Schedule5</p> <p>3 Writable if Out_Of_Service is true 5 max 6 time/value pairs</p>
<p><b>Trend Log</b></p>	<p>Acked_Transitions Align_Intervals Description Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Event_Time_Stamps Interval_Offset Last_Notify_Records Log_DeviceObjectProperty Log_Interval Notification_Class Notification_Threshold Notify_Type Records_Since_Notification Reliability_Evaluation_Inhibit Reliability Start_Time Stop_Time Trigger</p>	<p>None</p>	<p>Align_Intervals Buffer_Size Description (max 255 chars) Enable Event_Algorithm_Inhibit Event_Detection_Enable Event_Enable Event_Message_Texts_Config Interval_Offset Log_DeviceObjectProperty Logging_Type Log_Interval Notification_Class Notification_Threshold Object_Name (max 64 chars) Record_Count Reliability_Evaluation_Inhibit Start_Time Stop_Time Stop_When_Full Trigger</p>

**Table 40: Description of the Proprietary Properties of the Device Object\***

Proprietary Property	Datatype	Description	Writ-able	Value Range
77000	Unsigned	MACType of the server device	No	0=MS/TP 2=BACnet/IP
77001	OctetString	MACAddress of the server device	No	For MS/TP, 1 octet MAC address For BACnet/IP, by 6 octet IP/UDP port MAC address
77002	OctetString	IP Subnet for BACnet/IP MACTypes	No	255.255.255.0 for example
77003	OctetString	BACnet/IP UDP	No	(big endian) 0xBAC0, etc.
77004	OctetString	BBMD_Address	Yes	0.0.0.0 indicates no BBMD registration required
77005	Unsigned	BBMD_TimeToLive	Yes	In seconds
77006	Unsigned	MAC COM Port	No	0-6
77007	Unsigned	MS/TP Baud rate	No	9600, 19200, 38400, 57600, 76800, 115200
77008	Character String	Password (for ReinitializeDevice and Device Communication Control)	Yes	Max 32 chars (default=carel)
77017	Unsigned	The amount of time of non-activity (no client sending DataExpectingReply PDUs) for the BACnet server to be declared offline	Yes	In milliseconds
77018	Unsigned	The amount of time of silence before an external device to be declared offline	Yes	In seconds
77019	Boolean	The dumptrace/start packet tracing indicator	Yes	TRUE = start tracing BACnet packets into a fixed RAM buffer
77020	Boolean	Not used	Yes	Not used

**Table 41: Description of the Proprietary Properties of the Analog Input, Analog Output, Analog Value, Binary Input, Binary Output, Binary Value, Multistate Input, Multistate Output, Multistate Value, Integer Value and Positive Integer Value\*\***

Proprietary Property	Datatype	Description	Writ-able	Value Range
77009	Enumerated	The BACnet read/write feature of the Present_Value property  (Analog Input, Analog Output, Analog Value, Binary Input, Binary Output, Multistate Input, Multistate Output, Multistate Value, Integer Value, Positive Integer Value)	No	0=read-only 1=writeable (not commandable) 2=commandable  If hexadecimal 0x80 (decimal 128) is added to the value, the object accepts SubscribeCOV requests (for example 0x82 (130) means the object commandable and accepts SubscribeCOV requests)

**Proprietary Object Types Supported:**

None

**Data Link Layer Options:**

- BACnet IP, (Annex J)
- BACnet IP, (Annex J), Foreign Device
- ISO 8802-3, Ethernet (Clause 7)
- ATA 878.1, 2.5 Mb. ARCNET (Clause 8)
- ATA 878.1, EIA-485 ARCNET (Clause 8), baud rate(s)
- MS/TP master (Clause 9), baud rate(s): 19200, 36800, 57600, 76800
- MS/TP slave (Clause 9), baud rate(s):
- Point-To-Point, EIA 232 (Clause 10), baud rate(s):
- Point-To-Point, modem, (Clause 10), baud rate(s):
- LonTalk, (Clause 11), medium:
- BACnet/ZigBee (ANNEX O)
- Other:

**Device Address Binding:**

Is static device binding supported? (This is currently necessary for two-way communication with MS/TP slaves and certain other devices.)

- Yes  No

**Networking Options:**

- Router, Clause 6 - List all routing configurations, e.g., ARCNET-Ethernet, Ethernet-MS/TP, etc.
- Annex H, BACnet Tunneling Router over IP
- BACnet/IP Broadcast Management Device (BBMD)

Does the BBMD support registrations by Foreign Devices?

- Yes  No

Does the BBMD support network address translation?

- Yes  No

**Network Security Options:**

- Non-secure Device - is capable of operating without BACnet Network Security
- Secure Device - is capable of using BACnet Network Security (NS-SD BIBB)
- Multiple Application-Specific Keys:
- Supports encryption (NS-ED BIBB)
- Key Server (NS-KS BIBB)

**Character Sets Supported:**

Indicating support for multiple character sets does not imply that they can all be supported simultaneously

- ISO 10646 (UTF-8)
- IBM®/Microsoft® DBCS
- ISO 8859-1
- ISO 10646 (UCS-2)
- ISO 10646 (UCS-4)
- JIS X 0208

**If this product is a communication gateway, describe the types of non-BACnet equipment/networks that the gateway supports:**


N/A

## Converting Register Values to ASCII Characters

Table 42 lists the ASCII characters and their decimal and hexadecimal numbers.

**Table 42: ASCII Conversion Table**

Char	Decimal	Hexadecimal	Char	Decimal	Hexadecimal	Char	Decimal	Hexadecimal
(Space)	32	0x20	@	64	0x40	`	96	0x60
!	33	0x21	A	65	0x41	a	97	0x61
"	34	0x22	B	66	0x42	b	98	0x62
#	35	0x23	C	67	0x43	c	99	0x63
\$	36	0x24	D	68	0x44	d	100	0x64
%	37	0x25	E	69	0x45	e	101	0x65
&	38	0x26	F	70	0x46	f	102	0x66
'	39	0x27	G	71	0x47	g	103	0x67
(	40	0x28	H	72	0x48	h	104	0x68
)	41	0x29	I	73	0x49	i	105	0x69
*	42	0x2a	J	74	0x4a	j	106	0x6a
+	43	0x2b	K	75	0x4b	k	107	0x6b
,	44	0x2c	L	76	0x4c	l	108	0x6c
-	45	0x2d	M	77	0x4d	m	109	0x6d
.	46	0x2e	N	78	0x4e	n	110	0x6e
/	47	0x2f	O	79	0x4f	o	111	0x6f
0	48	0x30	P	80	0x50	p	112	0x70
1	49	0x31	Q	81	0x51	q	113	0x71
2	50	0x32	R	82	0x52	r	114	0x72
3	51	0x33	S	83	0x53	s	115	0x73
4	52	0x34	T	84	0x54	t	116	0x74
5	53	0x35	U	85	0x55	u	117	0x75
6	54	0x36	V	86	0x56	v	118	0x76
7	55	0x37	W	87	0x57	w	119	0x77
8	56	0x38	X	88	0x58	x	120	0x78
9	57	0x39	Y	89	0x59	y	121	0x79
:	58	0x3a	Z	90	0x5a	z	122	0x7a
;	59	0x3b	[	91	0x5b	{	123	0x7b
<	60	0x3c	\	92	0x5c		124	0x7c
=	61	0x3d	]	93	0x5d	}	125	0x7d
>	62	0x3e	^	94	0x5e	~	126	0x7e
?	63	0x3f	_	95	0x5f			



# COMPLETE HVAC SYSTEM SOLUTIONS

SELF-CONTAINED | ROOFTOPS | COILS | CONDENSING UNITS  
AIR HANDLERS | WATER-COOLED CHILLERS | AIR-COOLED CHILLERS  
MODULAR CENTRAL PLANTS | BUILDING CONTROLS  
UNIT HEATERS | FAN COILS | AIR PURIFIERS | WATER SOURCE HEAT PUMPS  
VARIABLE AIR VOLUME UNITS | UNIT VENTILATORS



13600 INDUSTRIAL PARK BLVD. | MINNEAPOLIS, MN 55441  
1-800-432-1342 | 763-553-5330

LEARN MORE AT  
**DAIKINAPPLIED.COM**