

# Installation and Maintenance Manual

# IM 1315

Group: **WSHP** Part Number: **910339001** Date: **January 2021** 

# **Dirty Filter Switch**




## **Dirty Filter Switch**

## **Included Parts:**

- Filter Differential Pressure Switch
- (2) 60" Black Wires with connectors
- (6) Cable Ties


## Installation

- Two field provided duct pressure taps will be required to install this sensor. Locate one tap in the ductwork upstream of the filter rack. Holes are provided in the top and bottom of the filter rack to locate the second tap.
- Mount sensor on the entering are duct near the location selected for the duct pressure. See Figure 2.
- Connect the field provided tube between the ductmounted tap and the high pressure (H) port on the sensor, and between the tap on the filter rack to the low pressure (L) port on the sensor.
- Run the wires provided from the sensor location to the unit.
- Connect the first wire from the Normally Open terminal on the sensor to pin 8 on the unit terminal strip.
  Connect the second wire from the Common terminal on the sensor to pin 21 on the unit terminal strip. Refer to Figure 3 and Figure 4 on page 3



### Figure 1: Mounting Holes Locations

Figure 2: Dirty Filter Switch and Sensing Tubes Location



### Figure 3: Unit Terminal Connections





Figure 4: Unit Terminals to Switch Terminals





#### Daikin Applied Training and Development

Now that you have made an investment in modern, efficient Daikin equipment, its care should be a high priority. For training information on all Daikin HVAC products, please visit us at www.DaikinApplied.com and click on Training, or call 540-248-9646 and ask for the Training Department.

### Warranty

All Daikin equipment is sold pursuant to its standard terms and conditions of sale, including Limited Product Warranty. Consult your local Daikin Applied representative for warranty details. Refer to Form 933-430285Y. To find your local Daikin Applied representative, go to www.DaikinApplied.com.

#### Aftermarket Services

To find your local parts office, visit www.DaikinApplied.com or call 800-37PARTS (800-377-2787). To find your local service office, visit www.DaikinApplied.com or call 800-432-1342.

This document contains the most current product information as of this printing. For the most up-to-date product information, please go to www. DaikinApplied.com.

Products manufactured in an ISO Certified Facility.